LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1252-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

JUNE 28, 1978 — THIS PERMIT EXPIRES

Dennis Buesing — ISSUED TO

3424 North 52nd Street, Lincoln, NE — ADDRESS

T12N, R6E, Section 26, Bl. 3, Lot 6, Addition Northridge — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1252-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 12/26/77

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 12N ; Range 6E ; Section 26
Block 3 ; Lot 6 ; Addition Northridge
Street Address _____

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
No. of Bedrooms 3 . Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Karen Gruesing
Signature of Applicant (Owner or Lessee)

3424 No. 52nd
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 12/27/77. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 12/27/77. Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 12/28/77 ACTION: Approved ☒ Disapproved ☐
Date Frwd. 12/28/77. Signature: Harry N. Sherwood

3. City or County Engineer: Date Rec'd. 12-28-77. ACTION: Approved ☑ Disapproved ☐
Date Frwd. 12-28-77. Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1252-C

DATE: 12/26/77

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 12N ; Range 6E ; Section 26 ; Block 3 ; Lot 6 ; Addition Northridge .
Street Address _____.

2. Property Use: Residential ☒ Commercial ☐
No. of Bedrooms 3
Other Use _____
Describe: _____

Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Kara Sweeney
Signature of Applicant (owner or lessee)

3424 N. 52nd
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 5/5/78 by: L.C.H.
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐ 12/27/77
by: Jerold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 5/5/78 by: Jerold C. Hood

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1252-C

PROPERTY WHERE SOIL TESTED:
Location: Township _____ : Range _____
Section & ¼ Sect. _____
Property Dimensions: 355 ft. x 400 ft.
Area: 3+ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ; Silty Clay Loam ; Sandy Loam on back
Silty Loam ; Clay Loam ; Sandy Clay

Owner: Dennis & Karen Buesing
Address: 3424 N. 52nd

Dates of Tests: 12/22 to 12/23. Weather: Precip. clear Temp. 45°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	32"	12/22	12:45	12/22	3:15	12/23	5:45	7½	6:15	6¼	30	1¼	
2	31"	"	"	"	"	"	"	6¼	"	4¼	"	2	
3	29"	"	"	"	"	"	"	7¼	"	4½	"	2¾	
4	33"	"	"	"	"	"	"	8	"	4½	"	3½	
5	33"	"	"	"	"	"	2:15	6¾	2:45	6½	"	¼	
6	30"	"	"	"	"	"	5:45	5¾	6:15	4¾	"	1	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Richard G. Ellison
Signature of Person Conducting Test

Address 3101 So 58th
Phone 488-8674

(Do not write below this line)


REVIEWING ACTION

REMARKS: Not ~~Pohocco Silty Clay Loam~~

DATE: December 27, 1972

Approved Percolation Rate (a)
A. 17 min./inch
B. _____ min./inch
C. _____ min./inch

Gerald C. Hood
Signature of Reviewing Official


370.8
50'
#6
160'
#5
holes spaced at approx. 25' intervals
#4
#3
#2
#1
60'
355
N
389.82
400.4
Northridge Lane

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1252-C

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material tile; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 24 in.
3. Distance between dwelling and septic tank 100 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 150 ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material conc.; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company tanner) No ☐
4. Manholes: Over Inlet; diam. 1 in.
Over Outlet; diam. 3 in.
Below Grade ___ in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet 9 in.
7. Depth of top of tank below finished grade 24 in.
8. Distances To:
Well or Suction Line 150 ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.

C. DISTRIBUTION BOX
1. Material conc.; No. available outlets 1.
2. Factory Built: Yes ☒ (Company tanner) No ☐
3. Dimension: Length 12 in.; Width 18 in. Depth 12 in.
4. Distance from Septic Tank 4 ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: moon tile
2. Lateral Lines: Depth below grade 28 in. Number 2; Length of each line ___ ft. Total length of Laterals 149 ft.; Slope 1/6 in/100 ft. Diameter of pipe 12 in.; Shape _____
Material: concrete ☒; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ___ ft.
3. Trench Dimensions. Depth 36 in.; Width 48 in.
4. Filter Material: gravel.
Depth of material from trench bottom 12 in.
5. Distances To:
Well or Suction Line 150 ft.;
Stream ___ ft.; Pressure Line ___ ft.
Property Line ___ ft.
6. Percolation Rate: _____ minutes/inch

TYPICAL SKETCHES



Karen Brasing
Signature of Applicant

Larry Schwarck

