LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 621-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF PERMIT

November 20, 1975
THIS PERMIT EXPIRES

Merle E. Wilken — Route #4 — Lincoln
ISSUED TO — ADDRESS

T10N; R5E; Sec. 5; Lot 6;
LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535	110.16	148.14	6-2
RECEIPTED BY	DATE	AMOUNT	

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 621-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: May 1, 1975

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10N ; Range 5E ; Section 5
   Block — ; Lot 6 ; Addition —
   Street Address Rt 4, LINCOLN

2. Property Use: Residential 3 ☒ ; Commercial ____ ☐
   No. of Bedrooms 8. Describe: ____
   11 people — 3 homes
   Other Use ____ ☐
   Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ (in use now) ; Other ☒

4. Distance to public sewer: none ft.

Merle E. Wilkage
Charlyn C. Olson
Merle E. Wilkage

Signature of Applicant (Owner or Lessee)

Rt 4 Lincoln

Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 5/20/75. Date Frwd. ____. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold E. Hood
2. Supt. Bldg. Insp.: Date Rec'd. ____. Date Frwd. ____. ACTION: Approved ☐ Disapproved ☐ Signature: Chas Seale
3. City or County Engineer: Date Rec'd. 5/28/75. Date Frwd. 5/28/75. ACTION: Approved ☒ Disapproved ☐ Signature: by MH

REMARKS OR REASONS FOR DISAPPROVAL ____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 621-C

DATE: May 1, 1975

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10 N ; Range 5 E ; Section 5 ; Block — ; Lot 6 ; Addition —.
Street Address Rt 4 LINCOLN.

2. Property Use: Residential 3 ☒ ; Commercial ☐
No. of Bedrooms 8 — 11 people — 3 homes
Other Use —
Describe: —
in use now

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ lagoon

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Merle E. Wilkens
Charles E. Wilkens
Merle E. Wilkens
Signature of Applicant (owner or lessee)

Rt 4, Lincoln
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; —
Filing Fee: $ 30.00

2. Site Visits:
Date: 7-16-75 by: jw
Date: — by: —
Date: — by: —

3. Date: Approved ☒ ; Disapproved ☐ 5/20/75
by: Jerrold E. Hoof

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7-16-75 by: James Wewerka

3' deep

10 people = 6000 cubic feet
Actually 6188

Round

Bottom 42'
Top 60'
Dike to Dike 72'

12 people = 7200 cubic feet
Actually 7187

Bottom 46'
Top 64'
Dike to Dike 76'

Square

10 people = 6000
Actually 6156

Bottom 36'
Top 54'
Dike to Dike = 68'


12 people = 7200 cubic feet
Actually 7284

Bottom 40'
Top 58'
Dike to Dike 70'

HD-45(73)


West side is 1:1.

SIDE VIEW



7-17-75
jw

Round or Oblong Lagoon



Fence

Inside edge of top of dike

Top

View

Square or Rectangular Lagoon

