LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

3140 "N" STREET Lincoln, NE 68510-1514 (402) 441-8000

NON TRANSFERABLE

PERMIT

No. 94390040901

Permit
SEWAGE SYSTEM REPAIR

Issued 08/16/94
Expires 02/16/95
Revenue Code 18754

Establishment
STUDEBAKER ENTERPRISES
T12N R6E SEC 24
19000 N 14 STREET

FEES: $50.00

TOTAL $50.00

Permittee
STUDEBAKER ENTERPRISES
BOX 00104
DAVEY NE 68336

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW "POST IN A PROMINENT PLACE"

RECEIVED AUG 12 1994

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 8-11-94

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 12 ; Range N1a ; Section 24 ;
Block _____ ; Lot _____ ; Addition _____
Street Address 19000 N 14th St. ½ N of Davey Rd.

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 4 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: Replacing 500 gal tank with 1000 and moving system east because of addition to house.

5. Work to be done by: Owner ☐ ; or Contractor ☒ , Buresh plumbing
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	2400 -

Studebaker Enterprises
Signature of Applicant (owner or lessee)

Box 104 Davey, Ne. 68336
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd: 8-16-94
Filing Fee: $ 50.00

2. Site Visits:
Date: 9-1-94 by: mm
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐
by: Jerrold E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 9-1-94 by: Ron Mayfield


N
E
House
70'
4" sewer
cleanout
60'
4" Sch 40
PVC sewer
50'
Precast
1500 gal
tank
21'
precast
d/s box
4"
28'
4"
28'
200'
well