LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Ave Lincoln, NE 68502-3785 (402) 471-8000

NON TRANSFERABLE

P E R M I T

Permit
SEWAGE SYSTEM REPAIR

No. 92390029001

Issued 08/07/92
Expires 02/07/93
Revenue Code 18754

Establishment
FRIESEN EXCAVATING
T12N R6E SEC 18

FEES: $50.00

TOTAL $50.00

Permittee
FRIESEN EXCAVATING
RR0001
LINCOLN NE 68502

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 8-4-92

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 12N ; Range 6E ; Section 18 SE ¼ ;
Block _____ ; Lot _____ ; Addition _____
Street Address _____

2. Property Use: Residential _____ ☐ ; Commercial _____ ☐
No. Bedrooms _____ Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☐ ; Other ☐

4. Description of proposed alteration, extension or repair: Added two more seepage beds 100 ft each to correct septic system in violation with 4" pipe discharge to ground surface

5. Work to be done by: Owner ☐ ; or Contractor ☐ , Friesen ~~Const~~ Excavating
Contractor's Name

6. Estimated cost of project:

a. Materials	$	>400 ea
b. Labor	$	
c. Other	$	
TOTAL	$	Excavating & Rubber Tired Loader

Friesen ~~Construction~~
Signature of Applicant (owner or lessee)

Rt #1, Lincoln, NE 68502
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd: 8-4-92
Filing Fee: $ 45.00

2. Site Visits:
Date: 8 4 92 by: mm
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐
by: Ron Hoyt

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 8-6-92 by: Ron Hoyt


House
Tank
Old
Barn
100 x 8'
100 x 8'
Add'l Bay
New

9208260003

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☒ Evaluation of the Individual Water System Date: 8-26-92

☒ Evaluation of the Sewage Disposal System ☒ Enclosed is $150.00

Legal Description of Property: TWP. 12N; RANGE 6E; SECTION 18, SE¼; BLOCK ___

LOT ___; ADDITION _____; Street Address 4400 Rock Creek Rd.

Directions to Property _____

Location of Well E. of House Tap Location: Inside ☐ Outside ☒

Location of Sewage System N. of House Year Installed ____

	NAME	ADDRESS	PHONE
Present Owner:	DOUG AND CAROLYN JOHNSON	4400 W. ROCK CREEK	
Tenant/Buyer:	ROBERT AND DEBRA BROOKS	5101 W. MULBERRY CIR	
Return to:			

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Robert Johnson Address 225 N. COTNER 68505

==========

HEALTH DEPARTMENT USE ONLY

Date Received 8-26-92 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 8-4-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☒ Corrected	Date 8-4-92 by JM
Bacteria	☒	☐	Provisional:	☒ Lg whole system	Date _____ by ____
Nitrate	☒	☐	Disapproved:	☒ failing system	Date _____ by ____

Comments: Failing septic system was corrected by adding a wide seepage bed subsurface disposal field. These experimental systems are given a provisional approval. Recommend checking to see if septic tank needs pumping. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:	
Approved: ☒	Approved: ☐	Provisional Approval: ☒

APPROVED BY Lon Mangum, RS DATE 8-26-92

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832