LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 993-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

June 30, 1977 — THIS PERMIT EXPIRES

Don Miller — ISSUED TO

Ceresco, Nebraska — ADDRESS

T9N; R6E; Section 34 — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

Health — ISSUING OFFICER

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 993-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 12-30-76

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

SEE ATTACHED

1. Legal description of property: Twp. 6N ; Range 12E ; Section 34
Block _____; Lot _____; Addition _____
Street Address _____ stac —

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
No. of Bedrooms 4 . Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: NA — ft.

Don Miller
Signature of Applicant (Owner or Lessee)

Cerasco, Nebraska
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 12/30/76 . Date Frwd. 12/30/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Gerald C. Head

2. Supt. Bldg. Insp.: Date Rec'd. 1-7-77 . Date Frwd. _____ . ACTION: Approved ☐ Disapproved ☒ Signature: Tom Baasch

3. City or County Engineer: Date Rec'd. 12/30/76 . Date Frwd. 1/5/77 . ACTION: Approved ☐ Disapproved ☒ Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 993-C

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto. SEE ATTACHED

1. Legal description of property: Twp. 6N ; Range 12E ; Section 34 ; Block ; Lot ; Addition .
Street Address .

2. Property Use: Residential ☒; Commercial ☐
No. of Bedrooms
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Don Miller
Signature of Applicant (owner or lessee)

Coresco, Nebraska
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: 10-5-77 by: jw
Date: 10-5-77 by: jw
Date: by:

3. Date: Approved ☒; Disapproved ☐ 12/30/76
by: Jerrold E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 10-5-77 by: James Weverka

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 993-C

SPECIFICATIONS

DATE: 12-30-76


A. BUILDING SEWER:
1. Material PVC 3034; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 18 in.
3. Distance between dwelling and septic tank 110 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 300 ft.;
Stream — ft.; Pressure Line 200 ft.;
Property Line 75 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Cement; No. of compartments ___.
2. Capacity 1250 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company precast)
No ☐
4. Manholes: Over Inlet; diam. 24 in.
Over Outlet; diam. ___ in.
Below Grade ___ in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade ___ in.
8. Distances To:
Well or Suction Line 300 ft.;
Stream — ft.; Pressure Line 200 ft.;
Property Line 75 ft.

C. DISTRIBUTION BOX
1. Material Cement; No. available outlets ___.
2. Factory Built: Yes ☒, (Company Pre Cast) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank ___ ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: lateral ditches
2. Lateral Lines: Depth below grade ___ in. Number 3; Length of each line ___ ft Total length of Laterals 266 ft.; Slope ___ in/100 ft. Diameter of pipe ___ in.; Shape ___
Material: concrete ☒; fiber asbestos ☐; clay ☐; other ___
Distance between lateral lines 15-20 ft.
3. Trench Dimensions: Depth 30 in.; Width 46 in.
4. Filter Material: gravel
Depth of material from trench bottom ___ in.
5. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.
Property Line ___ ft.
6. Percolation Rate: ___ minutes/inch

TYPICAL SKETCHES



Don Miller
Signature of Applicant

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 993-C

PROPERTY WHERE SOIL TESTED:
Location: Township 6N : Range 12E
Section & ¼ Sect. SE¼ 34
Property Dimensions: 460 ft. x 580 ft.
Area: _____ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ; Silty Clay Loam ; Sandy Loam
Silty Loam ; Clay Loam ; Sandy Clay

Owner: DE Miller
Address: Coresco, Ne.

Dates of Tests: 12-15-76 to 12-16-76. Weather: Precip. dry Temp. 20°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	30	12-15	10:00 AM	12-16	10:00 AM	12-16	3:00 PM	6	3:30	5¼	30	¾	
2	30						3:00	6	3:30	5	30	1	
3	32						3:00	6	3:30	0	30	6	
4	30						3:15	6	3:45	5¼	30	¾	
5	32						3:15	6	3:45	5⅛	30	⅞	
6	32						3:15	6	3:45	5	30	1	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Signature of Person Conducting Test
Address #1520 Pioneer Blvd.
Phone 423 0121

(Do not write below this line)

REVIEWING ACTION

REMARKS: Hole No. 3 dropped from results.


DATE: December 30, 1976

Approved Percolation Rate (a)
A. 34 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

Don Mueller

PLOT PLAN



LEGAL DESC.:

THE So. 580.0' OF THE North 1/2 OF THE E. 440' OF THE SE 1/4 OF Sec 34 T6N R12E OF THE 6th P.M., LANCASTER COUNTY, NEBR.

I HEREBY [illegible] THE ABOVE PLOT PLAN IS TRUE AND CORRECT [illegible] OF MY KNOWLEDGE.

NEBRASKA REGISTERED LS-252 LAND SURVEYOR

[signature]

Nov. 15, 1976