CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 373

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION

TYPE OF LICENSE OR PERMIT

June 13, 1974

THIS LICENSE OR PERMIT EXPIRES

Thomas M. Toogood

LICENSEE OR PERMITTEE

4621 Hartley

ADDRESS

T10N; R5E;of 6PM; Sec. 23; Lot 32 I.T.

NAME OF ESTABLISHMENT, IF ANY

LEGAL DESCRIPTION

ADDRESS

REMARKS:

NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-110.15	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 373

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 10 N.; Range 5E 6th; Section 23;
Block ____; Lot 3 & 4; Addition ____;
Street Address ____.

2. Property Use: Residential ____ ☐; Commercial ____ ☒
No. of Bedrooms ____. Describe: Body shop

Other Use ____ ☐
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Distance to public sewer: More ft.

Property at 8100 W. "O" Lincoln

Thomas M Toogood
Signature of Applicant (owner or lessee)

4621 Hartley Lincoln Neb 68504
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 12/13/73. Date Frwd. 12/13/73. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 12-13-73. Date Frwd. 12-13-73. ACTION: Approved ☒ Disapproved ☐ Signature: Chas Seek By Rob Shinn

3. City Engineer: Date Rec'd. ____. Date Frwd. 12-13-73. ACTION: Approved ☑ Disapproved ☐ Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL ____

FINAL ACTION ON SITE CLEARANCE: Approved ☒ Disapproved ☐

Date Applicant Notified: 6-12-74 Signature James Wierzba

FORM HD-32(67) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. _____

DATE: 12-11-73

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10N; Range 5E 6PM; Section 23;
Block _____; Lot 33; Addition _____;
Street Address _____.

2. Property Use: Residential _____ [ ]; Commercial _____ [X]
No. of Bed Rooms _____ Describe: Body Shop

Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Thomas M Toogood
Signature of Applicant (owner or lessee)

Property at 8100 W. "O" St. Lincoln

4621 Hartley Lincoln Neb 68504
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Date Site Clearance _____

3. Site Visits:
Date: 6-12-74 by: JW
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 12/13/73
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 6-12-74 by: James Wevelka

FORM HD-33(67) SOIL ABSORPTION
TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue 475-6221
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. _____

PROPERTY WHERE SOIL TESTED:
Location: Township _____
Section & ¼ Sect. _____
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Tom TooGood
Address 4621 Hartley Lincoln

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐ FILL
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Dates of Tests: Dec 1 73 to Dec 2 73. Weather: Precip. 0 Temp. 50° F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Pre-Saturation Period Start Time (Hr. Min.)	Pre-Saturation Period End Date (Mo. Day)	Pre-Saturation Period End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Percolation Readings Start Time (Hr. Min.)	Percolation Readings Start Water Level (in.)	Percolation Readings End Time (Hr. Min.)	Percolation Readings End Water Level (in.)	Results Elapsed Time (Min.)	Results Water Level Drop (in.)	Results Percolation Rates (Min./inch)
1	36	12/1	1:30 PM	12/2	1 PM	12/2	1 PM	12	2:30 PM	9	30M	3	
2	"	"	"	"	"	"	"	"	"	7½	"	1½	
3	"	"	"	"	"	"	"	"	"	6	"	1	
4	"	"	"	"	"	"	"	"	"	4¾	"	1	
5	"	"	"	"	"	"	"	"	"	3	"	1¾	
6	"	"	"	"	"	"	"	"	"	1¼	"	1¾	

Robert D Johnson
Signature of Person Conducting Test

Address 426 NW 13th
Phone: 432-3595

Sum of Percolation Rates _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 25 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: December 13, 1973

Jerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. _____

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material Clay; Diameter 4" in.
2. Distance above basement floor ___ in.; or below basement floor ___ in.
3. Distance between dwelling and septic tank 20 ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete; No. of compartments One.
2. Capacity 1000 gals.; Liquid depth 47 in.
3. Factory Built: Yes ☒ (Company _____) No ☐
4. Manholes: Over Inlet; diam. 9 in.
Over Outlet; diam. 9 in.
Below Grade _____ in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade ___ in.
8. Distances To:
Well or Suction Line 100 ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line 80 ft.

C. DISTRIBUTION BOX
1. Material Cement; No. available outlets 5.
2. Factory Built: Yes ☑, (Company Prr Cast Step Co) No ☐
3. Dimension: Length 20 in.; Width 14 in. Depth 12 in.
4. Distance from Septic Tank 4 ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: C-Crete
2. Lateral Lines: Depth below grade 12 in. Number 1; Length of each line ___ ft Total length of Laterals 50 ft.; Slope 4 in/100 ft. Diameter of pipe 24 in.; Shape ○
Material: concrete ☒; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth 40 in.; Width 48 in.
4. Filter Material: Rd Gravel. Depth of material from trench bottom 24 in.
5. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.
Property Line ___ ft.
6. Percolation Rate: _____ minutes/inch

TYPICAL SKETCHES



Thomas M Toogood
Signature of Applicant

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. _____

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material CLAY; Diameter 4" in.
2. Distance above basement floor ___in.; or below basement floor ___in.
3. Distance between dwelling and septic tank 20 ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ___ft.;
Stream ___ft.; Pressure Line ___ft.;
Property Line ___ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete; No. of compartments ONE.
2. Capacity 600 gals.; Liquid depth 47 in.
3. Factory Built: Yes ☒ (Company _____)
No ☐
4. Manholes: Over Inlet; diam. 9 in.
Over Outlet; diam. 9 in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☒
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ___in.
8. Distances To:
Well or Suction Line 100 ft.;
Stream ___ft.; Pressure Line ___ft.;
Property Line 80 ft.


C. DISTRICTION BOX
1. Material Cement; No. available outlets 5.
2. Factory Built: Yes ☒, (Company Precast Step Co) No ☐
3. Dimension: Length 20 in.; Width 14 in. Depth 12 in.
4. Distance from Septic Tank 4 ft.
5. Serial Distribution: Yes ☐, No ☒
(If yes, show detailed plans.)


D. ABSORPTION FIELD: (Provide drawings.)
1. Type: C-Crete
2. Lateral Lines: Depth below grade 12 in.
Number 1; Length of each line ___ft
Total length of Laterals 50 ft.;
Slope 4 in/100 ft. Diameter of pipe 24 in.; Shape ∩
Material: concrete ☒; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ___ft.
3. Trench Dimensions: Depth 40 in.;
Width 48 in.
4. Filter Material: Rd Gravel.
Depth of material from trench bottom 24 in.
5. Distances To:
Well or Suction Line ___ft.;
Stream ___ft.; Pressure Line ___ft.
Property Line ___ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



Thomas M Toogood
Signature of Applicant


52'
± 10'
6'
15'
N



Scale: 1 square = 5 ft.

Lot 32 - IRR. tract So. West quarter Sec 23 township 10 north range 5 east of the 6 PM, Lancaster Co.