LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 878-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

January 12, 1977 — THIS PERMIT EXPIRES

Randall A. Kaup — ISSUED TO

1300 West Commodore Drive, Lincoln 68522 — ADDRESS

TION; R5E; Sec. 27; Bl. 1; Lot3; Glad Acres Add.] LAGOON — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 878-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: July 12

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10 North Range 5 East ~~of 6th pm~~; Section 27
Block One ; Lot Three ; Addition Glad Acres
Street Address SW 92nd

2. Property Use: Residential ☒ ; Commercial ☐
No. of Bedrooms 3 . Describe:

Other Use ☐
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ Lagoon

4. Distance to public sewer: ——— ft.

Randall A. Zaruba
Signature of Applicant (Owner or Lessee)

1300 W. Commodore Rd.
Address

Lincoln, Nebr. 68522
435-3708

ak581

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 7/13/76 . Date Frwd. 7/13/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. . Date Frwd. 7/13/76 . ACTION: Approved ☒ Disapproved ☐ Signature: David Dale

3. City or County Engineer : Date Rec'd. 7/13/76 . Date Frwd. 7/13/76 . ACTION: Approved ☐ Disapproved ☒ Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 878-C

DATE: July 12, 1976

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10 North ; Range 5 East of 6th p.m. ; Section 27 NE¼ of NW¼ ; Block One ; Lot Three ; Addition Glad Acres .
Street Address SW 92nd .

2. Property Use: Residential ☑ ; Commercial ☐
No. of Bedrooms 3
Describe:

Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ Lagoon

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Randall A. Raup
Signature of Applicant (owner or lessee)

1300 W. Commodore Road
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: Dec-76 by: mm
Date: 1-10-77 by: mm
Date: by:

3. Date: Approved ☒ ; Disapproved ☐ 7/13/76
by: Jerrold C. Hoad

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 1-10-77 by: Ron Magnuson

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 878-C

PROPERTY WHERE SOIL TESTED:
Location: Township 10 North; Range 5 East of the 6th p.m.
Section & ¼ Sect. NE¼ of NW¼ of Sec 27
Property Dimensions: 420 ft. x 562 ft.
Area: 5.4 acres. (Attach sketch of property showing hole location).

Owner: Randall + Sherry Kaup
Address 1300 W. Commodore Rd. Lincoln, Nebr. 68522

Soil Type: Silty Clay ☐; Silty Clay Loam ☒; Sandy Loam ☐ with rocks
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☐

Dates of Tests: July 11, '76 to July 12, '76. Weather: Precip. Dry Temp. 96°

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch) Last 30 Minutes (Inches)
1	14"	7/11	3PM	7/11	9PM	7/12	5:30AM	7	9:30PM	12	240	5	48 1/4"
2	"	"	"	"	"	"	"	6	"	8 1/2	"	2 1/2	96 1/4"
3	"	"	"	"	"	"	"	3	"	8	"	5	48 3/8"
4	"	"	"	"	"	"	"	3 1/2	"	9 1/2	"	6	40 5/8"
5	"	"	"	"	"	"	"	1	"	4 1/2	"	3 1/2	68.6 1/4"
6	"	"	"	"	"	"	"	3	"	5 1/2	"	2 1/2	96 1/8"
7	"	"	"	"	"	"	"	2	"	8	"	6	40 1/2"
8	"	"	"	"	"	"	"	4	"	9	"	5	48 3/8"
9	"	"	"	"	"	"	"	4	"	8 3/4	"	4 3/4	50.5 1/2"
10	"	"	"	"	"	"	"	3	"	9 3/4	"	6 3/4	35.5 7/8"
11	"	"	"	"	"	"	"	5	"	11 3/4	"	6 3/4	35.5 3/8"

Sum of Percolation Rates 606
Average of Rates: 55
Mean of Rates: 49

Randall A. Kaup
Signature of Person Conducting Test

Address 1300 W. Commodore Rd.
Phone: 435-3708

Note* Holes 5 + 6 most accurately depict the type of soil which will be the bottom of the lagoon.

(Do not write below this line)

REVIEWING ACTION


REMARKS:

Approved Percolation Rate(s)
A. _____ min./inch
B. _____ min./inch
C. _____ min./inch

DATE: July 13, 1976

Gerrold C. Hood
Signature of Reviewing Official


(1/2 mile west of Emerald on Hwy 6, south 1/4 mile.)




Randall A. Rauf
1300 W. Commonlove Rd.
Lincoln, Nebr. 68522
435-3708

WASTE STABILIZATION POND

LINCOLN-LANCASTER CO. HEALTH DEPT.
DIVISION OF ENVIRONMENTAL HEALTH 2-75





SECTION VIEW A-A
(APPLICABLE TO BOTH DESIGNS)


NUMBER OF BEDROOMS IN THE HOUSE	MINIMUM LAGOON DIMENSIONS (FEET)					
	SQUARE			ROUND		
	A	B	C	A	B	C
2-3	49	37	19	52	40	22
4	56	43	25	57	48	30

ADDITIONAL INFORMATION ON BACK

SIGNATURE OF APPLICANT Randall C. Rauh

July 13, 76

HD-46(75)



(Side view of lagoon)
From A to B there is a slope of 5-6 ft.
Lagoon to be 49ft square - 3 bedroom house
2-3 ea. clean outs

005

Lincoln-Lancaster County Health Department

2200 St. Mary's Avenue, Lincoln, Nebraska 68502 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 301 SW 92nd St. - Rt. 6

Twp 10 North Range 5 East of 6th PM Section 27 1/4 NE 1/4 NW Block 1 Lot 3 Addition Glad Acre's

Directions to Property 1/2 mile west of Emerald, 1/4 mile south on SW 92nd St. - 3rd house on the right

Location of Well west of house Tap Location: Inside ☐ Outside ☒

Location of Sewage System ~170 ft SW of house (Lagoon) Year Installed 1977

	NAME	ADDRESS	PHONE
Present Owner:	Randall A. Kaup	301 SW 92nd St. - Rt. 6	(402) 475-5547
Tenant/Buyer:			
Return to:	Randall A. Kaup	301 SW 92nd St. Rt 6	475-5547

Signature of Applicant Randall A. Kaup Address 301 SW 92nd St. Rt 6 Lincoln, NE 68502 Date 9/24/93

HEALTH DEPARTMENT USE ONLY

Date Received 9/27/93 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By PAUL DROTZMAN **DATE:** 9/28/93

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☐	☒ Depression	Approved ☒	Date 9/29/93 by P.D
Bacteria	☒ 0 /ml	☐ /ml	Provisional ☐	Date / / by
Nitrate	☒ <0.1 ppm	☐ ppm	Disapproved ☐	Date / / by

Comments: No volatile organics or pesticides detected

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Paul Drotzman Date 10/20/93

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

185