LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 682-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

February 26, 1976 — THIS PERMIT EXPIRES

Michael D. Lewis — ISSUED TO

5328 W. Zeamer Lincoln, NE — ADDRESS

T10N; R5E; Sec 35 — LEGAL DESCRIPTION

REMARKS:

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$	$	$	$
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY | DATE | AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 682-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: Aug 8, 1975

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10N ; Range 5E ; Section 35
Block _____; Lot _____; Addition _____
Street Address Rt #6 Rural
SOUTH 313.07' OF WEST 208.71' OF THE SE¼

2. Property Use: Residential _____ ☒ ; Commercial _____ ☐
No. of Bedrooms 3 . Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: rural ft.

Michael D. Lewis
Signature of Applicant (Owner or Lessee)

5328 W. Zeamer Lincoln
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 8/26/75 . Date Frwd. 8/27/75 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 8-27-75 Date Frwd. 8-27-75 . ACTION: Approved ☐ Disapproved ☐ Signature: _____

3. City or County Engineer: Date Rec'd. 8-27-75 . Date Frwd. 8-27-75 . ACTION: Approved ☐ Disapproved ☐ Signature: Henry Graff Deputy

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 682-C

DATE: Aug 8, 1975

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10N ; Range 5E ; Section 35 ; Block ; Lot ; Addition SOUTH 313.07' OF WEST 208.71' OF THE SE1/4.
Street Address R+6 Rural.

2. Property Use: Residential ☒; Commercial ☐
No. of Bedrooms three
Describe:
Other Use
Describe:

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Michael D Lewis
Signature of Applicant (owner or lessee)

5328 W. Zeamer Lincoln
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd;
Filing Fee: $ 30.00

2. Site Visits:
Date: 4-8-76 by: jw
Date: by:
Date: by:

3. Date: Approved ☒; Disapproved ☐ 8/26/75
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 4-8-76 by: James Weverka

FORM HD- 43(73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 475-6221)

FILE NO. 682-C

PROPERTY WHERE SOIL TESTED:
Location: Township 10 ; Range 5
Section & ¼ Sect. 35 SE¼
Property Dimensions: 313.07 ft. x 208.71 ft.
Area: 1½ acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay [ ]; Silty Clay Loam [ ]; Sandy Loam [ ]
Silty Loam [ ]; Clay Loam [X]; Sandy Clay [ ]

Owner: Everett H. Giles
Address Rt. 6 Lincoln

Dates of Tests: Aug 5, 1975 to Aug 6, 1975. Weather: Precip. 0 Temp. 89 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36	8/5	5:24			8/6	8:00	6	8:31	3½	31	2½	
2	36	8/5	5:36			8/6	8:01	6	8:32	3½	31	2½	
3	37	8/5	5:40			8/6	8:02	6	8:33	4	31	2	
4	40	8/5	5:45			8/6	8:03	7	8:34	5½	31	1½	
5	35	8/5	5:56			8/6	8:04	6	8:35	5½	31	½	
6	36	8/5	6:00			8/6	8:05	6	8:36	5½	31	½	

Sum of Percolation Rates
Average of Rates:
Mean of Rates:

Michael D. Lewis
Signature of Person Conducting Test

Address 5328 W. Blanmer
Phone: 799-2272

(Do not write below this line)

REVIEWING ACTION

REMARKS:

Approved Percolation Rate(s)
A. 19 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: August 25, 1975

Jerrold C. Hood
Signature of Reviewing Official


KITCHEN PLANNING SHEET

ASHTON WHOLESALE SERVICE, INC.

PROJECT)
OWNER)
ADDRESS
UNITS
DATE
SOLD BY

OVEN
RANGE
REFRIG.

PRESTIGE



Well to House Apx 15'
" " " East Side 65'
" " Septic Tank 180'

100 of 4" Plastic to Tank
Will Permit Basement
Drains

Lateral Field Will Be
Buried Apx 20"-24".

Q ITEM

Each Square Equals Three Inches

TOPS
SINK
MED. CAB.
HOOD

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☑

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 682-C

SPECIFICATIONS

DATE: Aug. 8, 1975

A. BUILDING SEWER:

1. Material Cast ; Diameter 4" in.
2. Distance above basement floor ___ in.; or below basement floor 4 in.
3. Distance between dwelling and septic tank 100 ft.
4. Number of clean-outs 1 .
5. Distances To:
   Well or Suction Line 15 ft.;
   Stream ~ ft.; Pressure Line ~ ft.;
   Property Line 50 ft.

B. SEPTIC TANK (Provide construction drawings.)

1. Material Concrete No. of compartments 1 . PRECAST
2. Capacity 1000 gals.; Liquid depth 57 in.
3. Factory Built: Yes ☒ (Company PRECAST) No ☐
4. Manholes: Over Inlet; diam. 10 in.
   Over Outlet; diam. 10 in.
   Below Grade ___ in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☒
   Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 20 in.
8. Distances To:
   Well or Suction Line 165 ft.;
   Stream ___ ft.; Pressure Line ~ ft.;
   Property Line 50 ft.


C. DISTRIBUTION BOX

1. Material Concrete No. available outlets 5 .
2. Factory Built: Yes ☒, (Company Lee Cast Step Co) No ☐
3. Dimension: Length 18 in.; Width 14 in. Depth 20 in.
4. Distance from Septic Tank ___ ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)


D. ABSORPTION FIELD: (Provide drawings.)

1. Type: Half moon
2. Lateral Lines: Depth below grade 20 in. Number 2 ; Length of each line ___ ft Total length of Laterals 155 ft.; Slope 1/4 in/100 ft. Diameter of pipe 20 in.; Shape Half moon Material: concrete ☒; fiber asbestos ☐; clay ☐; other ___ Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth ___ in.; Width 48 in.
4. Filter Material: Road Gravel Depth of material from trench bottom ___ in.
5. Distances To:
   Well or Suction Line 165 ft.;
   Stream ___ ft.; Pressure Line ___ ft.
   Property Line 25 ft.
6. Percolation Rate: 19 minutes/inch

TYPICAL SKETCHES



Michael D. Lewis
Signature of Applicant


N
73'
12'
12" below surface
4'
8'
79'
15'
4'
9½'
8'
64'
92'
3' deep
4' wide
3' deep
4' wide
concrete
half moons
4-8-76