LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 2252-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

MARCH 6, 1986 — THIS PERMIT EXPIRES

J. R. WALTERS — ISSUED TO

ROUTE #3 — ADDRESS

LINCOLN, NE 68505

T11N; R8E; Sec 6; Lot 6 — LEGAL DESCRIPTION

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

HEALTH — ISSUING OFFICER

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. 2252-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 9-5-85

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☒ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 11N; Range 8E; Section SE 6;
Block ____; Lot 6; Addition ____
Street Address ____

2. Property Use: Residential ✓ ☐; Commercial ____ ☐
No. Bedrooms 3
Describe ____
Other Use ☐
Describe ____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☐; Other ☐

4. Description of proposed alteration, extension or repair: added 100 ft. of 4" laterals

5. Work to be done by: Owner ☐; or Contractor ☒, Larry Schunk
Contractor's Name

6. Estimated cost of project:

a. Materials	$
b. Labor	$
c. Other	$
TOTAL	$ over 400.00

J. R. Malta
Signature of Applicant (owner or lessee)

Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: 9-5-85
Filing Fee: $ 30.00

2. Site Visits:
Date: 9-5-85 by: mm (without 20 feet of right of way.)
Date: ____ by: ____
Date: ____ by: ____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hoop

4. INSTALLATION ~~FINAL~~ PROVISIONAL WRITTEN APPROVAL
Date: 9-5-85 by: Ron Morgan

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

D

DATE: _____

FILE NO. 2252-C


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material _____; Diameter _____ in.
2. Distance above basement floor _____ in., or below basement floor _____ in.
3. Distance between dwelling and septic tank _____ ft.
4. Number of clean-outs _____.
5. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material _____; No. of compartments _____.
2. Capacity _____ gals.;
3. Factory Built: Yes ☐ No ☐
(Company _____)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade _____ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade _____ in.
8. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material _____; Number - available outlets _____.
2. Factory Built: Yes ☐ No ☐
(Company _____)
3. Distance from Septic Tank _____ ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☒ Perforated Pipe ☐
Diameter of Half Round _____ or
Perforated Pipe _____.
Material: fiberglass ☐ ; plastic ☐ ; concrete ☒ ; other _____.
2. Lateral Lines:
Number 2 ; Length of each line 40', 60', _____, _____, _____ ft.;
Total length of laterals 100' ft.;
Distance between lateral lines _____ ft.
3. Trench dimensions: Width _____ ft.;
Slope 1" in/100 ft.; Average Depth 4' in.
4. Filter Material: Road Gravel
Depth of Material 20" in.
5. Distances to:
Well or Suction Line 100' + ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.
Road 20'



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE 9-5-85 INSTALLER Larry Schwarck

