CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 928

INDIVIDUAL SEWAGE SYSTEM CONTRUCTION
TYPE OF LICENSE OR PERMIT

April 5, 1977
THIS LICENSE OR PERMIT EXPIRES

Charlie Vogel
LICENSEE OR PERMITTEE

Route 4, Lincoln, Nebraska
ADDRESS

T 10N; R 6E; Sect. 2; Lot N½ of 10; Grove Park Subdivision ~~(809 West Fletcher)~~
NAME OF ESTABLISHMENT, IF ANY

Legal Description
ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
42494 001 5 76		30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 928

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10N ; Range 6E ; Section 2 ; Block ; Lot N½ OF 10 ; Addition GROVE PARK SUBDIVISION
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bedrooms 3
Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Charlie Vogel
Signature of Applicant (owner or lessee)

_____
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: _____ by: _____
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved [X]; Disapproved [ ] 10/5/76
by: _____

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: _____ by: _____

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 928

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: Oct. 5, 1976

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10N ; Range 6E ; Section 2
Block ____; Lot N½ of 10 Addition Grove Park Subdivision
Street Address ~~800 W Fletcher~~ 800 Block East Fletcher

2. Property Use: Residential ____ /xx/ ; Commercial ____ /__/
No. of Bedrooms 3 .
Describe: ____
Other Use ____ /__/
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank /xx/ ; Other /__/

4. Distance to public sewer: ____ ft.

Charles V Vogel
Signature of Applicant (Owner or Lessee)
(Charles V. Vogel)
RT 4
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/5/76 . Date Frwd. 10/5/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 10-5-76 . Date Frwd. 10-5-76 . ACTION: Approved ☒ Disapproved ☐ Signature: Williamson

3. City or County Engineer : Date Rec'd. 10/5/76 . Date Frwd. 10/5/76 . ACTION: Approved ☒ Disapproved ☐ Signature: Joe Bd

REMARKS OR REASONS FOR DISAPPROVAL ____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 928

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material CAST IRON; Diameter 4" in.
2. Distance above basement floor ___ in.; or below basement floor 12" in.
3. Distance between dwelling and septic tank 30 ft.
4. Number of clean-outs 1.
5. Distances To:
Well or Suction Line 150' ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material CONCRETE; No. of compartments _____.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes ☒ (Company PRECAST
No ☐
4. Manholes: Over Inlet; diam. 6" in.
Over Outlet; diam. 6" in.
Below Grade 12" in.
5. Inlet: Baffle ☐; or Tee ☒
6. Outlet: Baffle ☐; or Tee ☒
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 12" in.
8. Distances To:
Well or Suction Line 150' ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line 150' ft.

C. DISTRIBUTION BOX
1. Material CONCRETE; No. available outlets _____.
2. Factory Built: Yes ☒, (Company PRECAST No ☐
3. Dimension: Length 96" in.; Width 60 in. Depth 62" in.
4. Distance from Septic Tank ___ ft.
5. Serial Distribution: Yes ☐, No ☐
(If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: _____
2. Lateral Lines: Depth below grade 32 in.
Number 3; Length of each line 100' ft
Total length of Laterals 200 ft.;
Slope 2" in/100 ft. Diameter of pipe 20" in.; Shape HALF MOON
Material: concrete ☒; fiber asbestos ☐; clay ☐; other ___
Distance between lateral lines 15 ft.
3. Trench Dimensions: Depth 32 in.; Width 36 in.
4. Filter Material: COARSE GRAVEL
Depth of material from trench bottom 14 in.
5. Distances To:
Well or Suction Line 150 ft.;
Stream 10 ft.; Pressure Line ___ ft.
Property Line 150 ft.
6. Percolation Rate: 20 minutes/inch

TYPICAL SKETCHES



Signature of Applicant