FILE NO. 1684

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE DISPOSAL SYSTEM
TYPE OF LICENSE OR PERMIT

February 18, 1981
THIS LICENSE OR PERMIT EXPIRES

DONALD W. SPILKER
LICENSEE OR PERMITTEE

1201 FLETCHER AVE., LINCOLN NE 68521
ADDRESS

T10N, R6E, Section 3, Lot 4 I.T.
NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON-TRANSFERABLE (Repair)

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	110.16	148.14	6-2

SERIAL NO. DATE AMOUNT

55721 NOV 19 30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

RECD AUG 18 1980

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1684

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 13 aug 80

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☐, or REPAIR ☒ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10 N ; Range 6 ; Section 3 ;
Block ____; Lot 4 I.T.; Addition ____
Street Address ____

2. Property Use: Residential X ☒; Commercial ____ ☐
No. Bedrooms 1
Describe ____
Other Use ☐
Describe ____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: installed new lateral & line from septic tank to lateral

5. Work to be done by: Owner ☐ ; or Contractor ☒ , Wayne Heidtbrink
Contractor's Name

6. Estimated cost of project:

a. Materials	$	495 —
b. Labor	$	
c. Other	$	
TOTAL	$	495 —

Donald W Spieker
Signature of Applicant (owner or lessee)

R#5 - Lincoln Neb
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 30.00

2. Site Visits:
Date: ____ by: J.C.H.
Date: ____ by: ____
Date: ____ by: ____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 8/19/80 by: J.C. Hood

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: 13 Aug 80

FILE NO. 1684


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material_____; Diameter_____in.
2. Distance above basement floor_____ in., or below basement floor_____in.
3. Distance between dwelling and septic tank_____ft.
4. Number of clean-outs_____.
5. Distances to:
Well or Suction Line_____ft.; Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.

B. SEPTIC TANK:
1. Material_____; No. of compartments_____.
2. Capacity_____gals.;
3. Factory Built: Yes ☐ No ☐
(Company_____)
4. Manholes: Over Inlet; diam._____in.
Over Outlet; diam._____in.
Riser Above ☐ Below ☐ Grade____in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade_____in.
8. Distances to:
Well or Suction Line_____ft.; Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.

C. DISTRIBUTION BOX:
1. Material_____; Number - available outlets_____.
2. Factory Built: Yes ☐ No ☐
(Company_____)
3. Distance from Septic Tank_____ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☒ Perforated Pipe ☐
Diameter of Half Round 24" or
Perforated Pipe_____.
Material: fiberglass ☐ ;plastic ☐ ; concrete ☒ ; other_____.
2. Lateral Lines:
Number 1 ;Length of each line 52, _____, _____, _____, _____ft.;
Total length of laterals 52 ft.;
Distance between lateral lines____ft.
3. Trench dimensions: Width 4 ft.;
Slope 4 in/100 ft.; Average Depth 3 ft to ~~in~~. Bottom
4. Filter Material: Gravel
Depth of Material 20 in. in.
5. Distances to:
Well or Suction Line_____ft.; Stream_____ft.; Pressure Line _____ft.; Property Line_____ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE 13 Aug 80 INSTALLER Wayne Heidtbrink

