CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 88

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

July 16, 1969
THIS LICENSE OR PERMIT EXPIRES

Myrtle D. Roach
LICENSEE OR PERMITTEE

1632 West Rose
ADDRESS

T 10N; R 6E; Sec. 15; Blk. 28; Lot 22,23,24; 1st add. to West Lincoln
NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
143 110.1535	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
14931	JAN 6 '69	30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-31(67) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 88

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: January 16, 1969

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with Lincoln City Ordinance No. 9150, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10N; Range 6E; Section 15;
Block 28; Lot 22,23,24; Addition 1ST ADDITION TO WEST LINCOLN
Street Address 2601 NORTH WEST 4TH ST.

2. Property Use: Residential ☒; Commercial ☐
No. Bedrooms ____ Describe ____

Other Use ☐
Describe ____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: ADDITION OF DISTRIBUTION BOX AND TWO 67 FT. ORANGEBURG LATERALS TO SEPTIC SYSTEM

5. Work to be done by: Owner ☐; or Contractor ☒, SINTEK PUMPING SERVICE
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	

Signature of Applicant (owner or lessee)

Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 30.00

2. Date Site Clearance: ____

3. Site Visits:
Date: ____ by: L. C. H.
Date: ____ by: ____
Date: ____ by: ____

4. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Wood

5. BUREAU OF LICENSES & PERMITS
Date Notified: ____
Date Issued: ____ Serial ____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 1/16/69 by: L. C. H.

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 88

SPECIFICATIONS

DATE: _____

A. BUILDING SEWER:

1. Material _____; Diameter ____ in.
2. Distance above basement floor ____in.; or below basement floor ____in.
3. Distance between dwelling and septic tank ____ft.
4. Number of clean-outs _____.
5. Distances To:
   Well or Suction Line ____ft.;
   Stream ____ft.; Pressure Line ____ft.;
   Property Line ____ft.

B. SEPTIC TANK (Provide construction drawings.)

1. Material CON; No. of compartments _____.
2. Capacity _____gals.; Liquid depth ____in.
3. Factory Built: Yes ☐ (Company _____)
   No ☒
4. Manholes: Over Inlet; diam. ____in.
   Over Outlet; diam. ___in.
   Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
   Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ____in.
8. Distances To:
   Well or Suction Line ____ft.;
   Stream ____ft.; Pressure Line ____ft.;
   Property Line ____ft.

C. DISTRIBUTION BOX NEW CONSTRUCTION


1. Material CON; No. available outlets 5.
2. Factory Built: Yes ☒, (Company PRE-CAST STEP No ☐
3. Dimension: Length ____in.; Width ___in. Depth ____in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

NEW CONSTRUCTION


D. ABSORPTION FIELD: (Provide drawings.)

1. Type: ORANGE BURG
2. Lateral Lines: Depth below grade __in. Number 2; Length of each line 67 ft Total length of Laterals 134 ft.; Slope 4 in/100 ft. Diameter of pipe 4 in.; Shape ROUND Material: concrete ☐; fiber asbestos ☒; clay ☐; other _____ Distance between lateral lines 6 ft.
3. Trench Dimensions: Depth 36 in.; Width 36 in.
4. Filter Material: GRAVEL. Depth of material from trench bottom _____in.
5. Distances To:
   Well or Suction Line ____ft.;
   Stream _____ft.; Pressure Line ____ft.
   Property Line ____ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



Signature of Applicant


N
W
E
S
6'
67'
67'
SHED
8'
10'
HOUSE
DRAINAGE WAY