FILE NO. 312

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

May 27, 1973 — THIS LICENSE OR PERMIT EXPIRES

Jerry Sundberg — LICENSEE OR PERMITTEE

Route #3 — ADDRESS

T11N; R7E; Sec. 36; (SW 1/4); Lot 5

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

LEGAL DESCRIPTION

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
110.15	110.16	148.14	6-2

624-1535

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 312

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 11N; Range 7E; Section 36; SW¼
Block ____; Lot 5; Addition _____;
Street Address _____.

2. Property Use: Residential _____ ☒ 3; Commercial _____ ☐
No. of Bedrooms _____. Describe: _____

Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Distance to public sewer: _____ ft.

Jerry Sundberg
Signature of Applicant (owner or lessee)

RT 3
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 11/24/72. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 11/27/72. Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 11-27-72. ACTION: Approved ☐ ☒ Disapproved ☐
Date Frwd. 11-27-72. Signature: Charles Teal By BL

3. City Engineer: Date Rec'd. _____. ACTION: Approved ☐ ☐ Disapproved ☐
Date Frwd. 11-27-72. Signature: _____

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☐ Disapproved ☐

Date Applicant Notified: _____ Signature _____

FORM HD-32(67) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 312

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 11 N; Range 7E; Section 36; Block _____; Lot 5; Addition _____; Street Address _____. SW¼

2. Property Use: Residential _____ [3]; Commercial _____ [ ]
No. of Bed Rooms _____ Describe: _____
Other Use _____ [ ]
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Jerry Sandberg
Signature of Applicant (owner or ~~lessee~~)

RT 3
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Date Site Clearance _____

3. Site Visits:
Date: 4/23/73 by: J.C.H.+O.d.
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 11/24/72
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 4/23/73 by: Jerrold C. Hood

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 312

PROPERTY WHERE SOIL TESTED:
Location: Township 11 7 36
Section & ¼ Sect. SW¼
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).

Owner: Jerry Sandberg
Address RT 3

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☒; Sandy Clay ☐

Dates of Tests: _____ to _____. Weather: Precip. ____ Temp. ____ F

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Pre-Saturation Period Start Time (Hr. Min.)	Pre-Saturation Period End Date (Mo. Day)	Pre-Saturation Period End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Percolation Readings Start Time (Hr. Min.)	Percolation Readings Start Water Level (in.)	Percolation Readings End Time (Hr. Min.)	Percolation Readings End Water Level (in.)	Results Elapsed Time (Min.)	Results Water Level Drop (in.)	Results Percolation Rates (Min./inch)
1	36	OCT 20	10:00	OCT 21	10:00	OCT 21	10:00	30	12:00		2 hrs	4	
2												4	
3												3	
4												4	
5												5	
6												4	

Sum of Percolation Rates
Average of Rates:
Mean of Rates: 4 in 2 hours

Signature of Person Conducting Test

Address 489-8208
Phone: _____

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 30 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: November 24, 1972

Gerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 312

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material PLASTIC; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor ___ in.
3. Distance between dwelling and septic tank 139½ ft.
4. Number of clean-outs 3.
5. Distances To:
Well or Suction Line 62 ft.;
Stream — ft.; Pressure Line — ft.;
Property Line 20+ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material FIBERGLASS; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth 48 in.
3. Factory Built: Yes ☒ (Company CORRUGATED FIBERGLASS) No ☐
4. Manholes: Over Inlet; diam. 12 in.
Over Outlet; diam. ___ in.
Below Grade 24 in.
5. Inlet: Baffle ☒; or Tee ☐
6. Outlet: Baffle ☒; or Tee ☐
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 24 in.
8. Distances To:
Well or Suction Line 100+ ft.;
Stream — ft.; Pressure Line — ft.;
Property Line 15 ft.


C. DISTRIBUTION BOX
1. Material CON; No. available outlets 5.
2. Factory Built: Yes ☒, (Company PRE-CAST STEP) No ☐
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 13½ ft.
5. Serial Distribution: Yes ☐, No ☒ (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: HALF Round
2. Lateral Lines: Depth below grade ___ in.
Number 2; Length of each line 100 ft
Total length of Laterals 188 ft.; ~~188~~
Slope 4 in/100 ft. Diameter of pipe 16 in.; Shape O
Material: concrete ☐; (fiber) asbestos ☐; clay ☐; ~~other~~ ___
Distance between lateral lines 12 ft.
3. Trench Dimensions: Depth 48 in.; Width 48 in.
4. Filter Material: Grade 2.
Depth of material from trench bottom ___ in.
5. Distances To:
Well or Suction Line 100+ ft.;
Stream — ft.; Pressure Line — ft.
Property Line 20 ft.
6. Percolation Rate: 30 minutes/inch

TYPICAL SKETCHES



Signature of Applicant


PROPERTY LINE
32'
12'
100'
88'
N
W
E
S
15'
13½'
13½'
LINE
SHED
38'
CLEANOUT
10½'
WELL
62'
14'
HOUSE
PROPERTY

INTER-DEPARTMENT COMMUNICATION

TO: Charles Seale

DEPARTMENT: Building Inspections

ATTENTION:

CARBONS TO:

DATE: November 27, 1972

FROM: Jerrold C. Hood

DEPARTMENT: Health

SUBJECT: Individual Sewage System Construction
File No. 312
Jerry Sundberg, Route #3

The application and plans have been reviewed and approved for the construction of an individual sewage disposal system on property legally described as:

T11N; R7E; Sec. 36 (SW 1/4); Lot 5

Jerrold C. Hood, R. S., Chief
Section of General Sanitation
Division of Environmental Health

JCH: ch