FILE #2465

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF LICENSE OR PERMIT

SEPTEMBER 13 1987 — THIS LICENSE OR PERMIT EXPIRES

JOHN S. PRAY — LICENSEE OR PERMITTEE

10500 NO. 84 STREET — ADDRESS

LINCOLN NE 685176

T11N; R7E; Sec SW¼ 24; Lot 3 I.T.; 84th & Bluff Rd — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 30.00	010754	$ 30.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: Mar 9 - 87

The undersigned hereby applies for a permit to ALTER [/], EXTEND [X], or REPAIR [ ] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 11N ; Range 7E ; Section SW¼ 24-
Block _____ ; Lot 3 I.T. ; Addition _____
Street Address 84th & Bluff Rd

2. Property Use: Residential _____ [ ]; Commercial _____ [ ]
No. Bedrooms 2 Describe _____
Other Use [ ]
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Description of proposed alteration, extension or repair: add Distribution Box and 50' of perforated pipe lateral

5. Work to be done by: Owner [ ] ; or Contractor [X] , Schwarck Trenching
Contractor's Name

6. Estimated cost of project:

a. Materials	$	350
b. Labor	$	350
c. Other	$	
TOTAL	$	700

John D Bry
Signature of Applicant (owner or lessee)

84th & Bluff Rd.
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 3/9/87 by: L.C.H. ~~Hood~~
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved [X]; Disapproved [ ]
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 3/13/87 by: L.C. Hood

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: _____

FILE NO. _____


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material _____; Diameter _____ in.
2. Distance above basement floor _____ in., or below basement floor _____ in.
3. Distance between dwelling and septic tank _____ ft.
4. Number of clean-outs _____.
5. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material _____; No. of compartments _____.
2. Capacity _____ gals.;
3. Factory Built: Yes ☐ No ☐
(Company _____)
4. Manholes: Over Inlet; diam. _____ in.
Over Outlet; diam. _____ in.
Riser Above ☐ Below ☐ Grade _____ in.
5. Inlet: Baffle ☐ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☐
7. Depth of top of tank below finished grade _____ in.
8. Distances to:
Well or Suction Line _____ ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Pre Cast ; Number - available outlets _____.
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 6' ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☐ Perforated Pipe ☒
Diameter of Half Round _____ or
Perforated Pipe 4" .
Material: fiberglass ☐ ; plastic ☐ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number 1 ; Length of each line 50, _____, _____, _____, 50' ft.;
Total length of laterals A ft.;
Distance between lateral lines _____ ft.
3. Trench dimensions: Width 3 ft.;
Slope 3" in/100 ft.; Average Depth 36" in.
4. Filter Material: Rock Gravel
Depth of Material 16 in.
5. Distances to:
Well or Suction Line 100' ft.;
Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.



TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE March 9 - 87 INSTALLER Larry Schwaneke

84th & Bluff Rd

John Brey

