FILE NO. 1883

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

DECEMBER 2, 1982
THIS LICENSE OR PERMIT EXPIRES

RICHARD HOSEK 3901 NORTH 42 STREET LINCOLN NE
LICENSEE OR PERMITTEE ADDRESS

T10N, R6E, SECTION NE¼ 30, BLOCK 6 & 7
NAME OF ESTABLISHMENT, IF ANY ADDRESS

REMARKS: NONTRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
61070 JW 82		30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION
HEALTH

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1883

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 5-24-82

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☒ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10 N ; Range 6E; Section NE¼ Section 30 ;
Block 647 ; Lot _____ ; Addition Cushman a subdivision
Street Address 4701 West O Street

2. Property Use: Residential X ☐; Commercial _____ ☐
No. Bedrooms 3 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: Replace tank) and install lateral 750 sq. ft.

5. Work to be done by: Owner ☐ ; or Contractor ☐ , ?
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	1000 -

Richard J. Hood
Signature of Applicant (owner or lessee)

3401 N. 42nd Lincoln, Neb
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 6/21/82 by: L.C.H.
Date: 6/21/82 by: L.C.H.
Date: 6/28/82 by: L.C.H.

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 6/28/82 by: L.C. Hood

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. _____

PROPERTY WHERE SOIL TESTED:

Location: Township 10 ; Range 6 ; Section & ¼ Section NE¼.
Property Dimensions: 160 ft. x 500 ft. Area: 1.18 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☐ ; Silty Clay Loam ☒ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: May 27 to May 28 . Weather: Precip. .40 Temp. upper 60's

OWNER: Richard J. Hosek

Address: 4701 West O Street

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	5-27	3:30	5-28	3:35	3:35	5-28	6"	7:35		30 min 4 hr	1 1/8	
2	33	5-27	3:30	5-28	3:35	3:35	5-28	6"	7:35		30 min 4 hr	1/4	
3	30	5-27	3:30	5-28	3:35	3:35	5-28	6"	4:05		30 mi	3/4	
4	27	5-27	3:30	5-28	3:35	3:35	5-28	6"	4:05		30 mi	1 3/8	
5	33	5-27	3:30	5-28	3:35	3:35	5-28	6"	4:05		30 mi	5/8	
6	36	5-27	3:30	5-28	3:35	3:35	5-28	6"	7:35		30 min 4 hr	1	

Richard J Hosek
Signature of Person Conducting Test

Address 3901 N 42nd Lincoln Ne Phone 464-9648

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)

REVIEWING ACTION

Remarks: Seems fast
Soil Type (SCS): Wymore Silty Clay Loam
Date: June 2, 1982

Approved Percolation Rate (a)
A. 30 min./inch
B. _____ min./inch
C. _____ min./inch

Jerrold C. Hood
Signature of Reviewing Official