# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 654

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

January 14, 1976
THIS LICENSE OR PERMIT EXPIRES

Mrs. Bob Gilliam — Route 7, Lincoln
LICENSEE OR PERMITTEE — ADDRESS

T10N, R6E, Sec. 31, Pl. 2; Lot 5; High Ridge West Acres 1st Addn.
NAME OF ESTABLISHMENT, IF ANY — ADDRESS

LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

| PERMIT | INSPECTION FEE | OCCUPATION TAX | LICENSE | TOTAL |
|---|---|---|---|---|
| $ 30.00 | $ | $ | $ | $ 30.00 |

| ACCOUNTING NO. | ACCOUNTING NO. | ACCOUNTING NO. | CODE |
|---|---|---|---|
| 110.15 | 110.16 | 148.14 | 6-2 |

| SERIAL NO. | DATE | AMOUNT |
|---|---|---|
| 624 | | |

APPLICATION

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 654

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 7-13-75

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10N ; Range 6E ; Section 31
Block 2 ; Lot 5 ; Addition High Ridge West Acres 1st addition
Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐
No. of Bedrooms 3. Describe: _____
Other Use ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Mrs. Audrey Gilliam
Signature of Applicant (Owner or Lessee)

Rt. # 7 Lincoln
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 7/14/75. Date Frwd. 7/14/75. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 7-14-75. Date Frwd. 7-14-75. ACTION: Approved ☒ Disapproved ☐ Signature: Williamson

3. City ~~or County~~ Engineer: Date Rec'd. 7-14-75. Date Frwd. 7-14-75. ACTION: Approved ☒ Disapproved ☐ Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 654

DATE: 7-13-75

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10N ; Range 6E ; Section 31 ; Block 2 ; Lot 5 ; Addition Highridge West Acres 1st Addition
Street Address _____.

2. Property Use: Residential _____ [X]; Commercial _____ [ ]
No. of Bedrooms 3 Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Mrs. Bob Gillean
Signature of Applicant (owner or lessee)

Rt. #7 Lincoln
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 10-24-75 by: [illegible]
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved [X]; Disapproved [ ] 7/14/75
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 10-24-75 by: James Wevelka

3 bedroom

Lot 5, Block 2

High Ridge West acres 1st add

$14\frac{1}{2} - 15 = \frac{1}{2}$

$14 - 14\frac{1}{2} = \frac{1}{2}$

$16 - 16\frac{1}{2} = \frac{1}{2}$

$16\frac{1}{4} - 16\frac{7}{8} = .625$

$23\frac{1}{4} - 23\frac{7}{8} = .625$

$26\frac{7}{8} - 27\frac{1}{2} = .625$

53 MIN/IN
313' lateral 3 wide

.5625

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1054

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material plastic; Diameter 4 in.
2. Distance above basement floor 4 in.; or below basement floor ___ in.
3. Distance between dwelling and septic tank 59 ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Concrete; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth ___ in.
3. Factory Built: Yes [X] (Company Pre Cast)
No [ ]
4. Manholes: Over Inlet; diam. ___ in.
Over Outlet; diam. ___ in. riser to surface
Below Grade _____ in.
5. Inlet: Baffle [ ]; or Tee [ ]
6. Outlet: Baffle [ ]; or Tee [ ]
Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade ___ in.
8. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.;
Property Line ___ ft.


C. DISTRIBUTION BOX
1. Material Concrete; No. available outlets 6.
2. Factory Built: Yes [X], (Company Pre-Cast) No [ ]
3. Dimension: Length ___ in.; Width ___ in. Depth ___ in.
4. Distance from Septic Tank 10 ft.
5. Serial Distribution: Yes [X], No [ ] (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Flexible black pipe
2. Lateral Lines: Depth below grade ___ in. Number 4; Length of each line ___ ft Total length of Laterals 313 ft.; Slope ___ in/100 ft. Diameter of pipe ___ in.; Shape round
Material: concrete [ ]; fiber asbestos [ ]; clay [ ]; other plastic
Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth ___ in.; Width 36 in.
4. Filter Material: gravel.
Depth of material from trench bottom ___ in.
5. Distances To:
Well or Suction Line ___ ft.;
Stream ___ ft.; Pressure Line ___ ft.
Property Line ___ ft.
6. Percolation Rate: 53 minutes/inch

TYPICAL SKETCHES




Signature of Applicant




3' wide

jw

short 6', but approved because soil was dark. Perc test was run on the east side of house