FILE NO. 1641

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

September 7, 1980
THIS LICENSE OR PERMIT EXPIRES

Ernest H. Gaube, Jr. 2317 South Coddington Ave., Lincoln, NE 68522
LICENSEE OR PERMITTEE — ADDRESS

T10N, R6E, Section 33, Lot 113 I.R.
NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
018754	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT
530924	7	30.00

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1641

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: December 23, 1979

The undersigned hereby applies for a permit to ALTER [ ], EXTEND [ ], or REPLACE ~~REPAIR~~ [x] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10 N ; Range 6 E ; Section 33 ;
Block ____ ; Lot 113 ; Addition Irregular tract in SW¼ exc. E. 50.0'
Street Address 2317 S. Coddington Ave.

2. Property Use: Residential ____ [x] ; Commercial ____ [ ]
No. Bedrooms 3
Describe ____
Other Use [ ]
Describe ____

3. Type of existing Individual Sewage Disposal System: Septic Tank [x] ; Other [ ]

4. Description of proposed alteration, extension or repair:
old septic tank destroyed and lagoon system established

5. Work to be done by: Owner [ ] ; or Contractor [x] , Larry Felton/Dale Tobler
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	1200 00
c. Other	$	
TOTAL	$	1200 00

Ernest H Gaube Jr.
Signature of Applicant (owner or lessee)

2317 S. Coddington Av. Lincoln, NE 68522
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 30.00

2. Site Visits:
Date: Aug-82 by: rm
Date: ____ by: ____
Date: ____ by: ____

3. Date: Approved [X] ; Disapproved [ ]
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: ____ by: ____

We, Wayne A Zimmerman and Jeanette L Zimmerman understand that the legal distance from the lot line for the placement of a lagoon septic system is 50 feet. However, we hereby give our approval to Ernest H. Gaube, Jr. and Olive E. Gaube to place their lagoon closer to our lot line. The lagoon will be approximately 20 feet from our lot line.

Dated this 19th day of December, 1979.

Wayne A Zimmerman

Jeanette L Zimmerman

FILE #W-212

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL WATER WELL CONSTRUCTION — TYPE OF LICENSE OR PERMIT

FEBRUARY 05, 1988 — THIS LICENSE OR PERMIT EXPIRES

ERNEST H. GAUPP — LICENSEE OR PERMITTEE

2317 SO. GODDINGTON AVE — ADDRESS

LINCOLN, NE, 68522

T10N; R6E; Sec 33; Lot 113 — NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

PERMIT	ACCOUNTING NUMBER	TOTAL
$ 45.00	019851	$ 45.00

Valid Receipt Only if Machine Receipted In This Space

Serial No. — Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM: 20222-0483
REQUEST FOR SITE CLEARANCE AND PERMIT FOR INDIVIDUAL WATER WELL

LINCOLN LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN, NEBRASKA 68502
PHONE: 471-7800

FILING FEE $ 45.00

FILE NO. W-212

DATE: 8-20-87

The undersigned hereby requests: Site Clearance and Permit to construct a new individual water well ☒ ; Permit existing well ☐ ; well repair or alteration involving opening of well ☐ ; in conformance with appropriate ordinance, as described herein:

1. Legal description of property: Twp. 10N : Range 6E : Section 33
   Block _____ : Lot 113 Except A50 ; Addition _____
2. Well use: Residential ☒ ; Commerical ☐ ; Other Use ☐
   Describe Household
3. Distance to Public Water Supply: Over 200 Ft.
4. Intended use of well domestic

Ernest H Saube
Signature of Applicant (owner or lessee)

2317 So Coddington
Address

NO CITY WATER

Sewage Permit Applied For Yes ☐ No ☐ Not Applicable ☒

1. Health Department: Date Rec'd 8-20-87. Action: Approved ☒ Disapproved ☐
   Date Frwd. 8/25/87. Signature: Jerrold C. Wood
2. Supt. Bldg. Insp.: Date Rec'd 8-25-87. Action: Approved ☒ Disapproved ☐
   Date Frwd. 8-25-87. Signature: Paul Baum
3. City or County Engineers: Date Rec'd 8/25/87. Action: Approved ☒ Disapproved ☐
   Date Frwd. 8/25/87. Signature: Jerome D. Abril

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 8-20-87 by _____ Site location
Date: 10/21/87 by J.C. Hood
Date: 11/30/87 by J.C. Hood
3/10/88 J.C. Hood Redrilled

Nitrate Level < 0.1 PPM CHLORIDE 62 P.P.M.
Bacteriological Analysis Satisfactory
Yes ☒ No ☐

INSTALLATION FINAL WRITTEN APPROVAL
Date: 12/4/87 By: J.C. Hood

Health Department copy: White
Engineers Copy: Light Green
Building Inspectors Copy: Light Blue

FORM 23-13

FORM: 20223-0483
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL WATER WELL
CITY ORDINANCE NO. 13558
FILE NO. W-212

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
2200 ST. MARYS AVENUE
LINCOLN NE 68502
Phone: 471-7800

OCT 27 1987

DATA SHEET FOR WATER WELLS

Legal Description: Sec. 33 T. 10N R. 6E Block ____ Lot 113 IT Addition ____

Owner Earnest Goube Address Cookington

LOG OF WELL	
	Description
Depth Ft. to	
0-10	tan c.
10-15	black c.
15-30	loose sand & clay
30-55	yell sh & some ss
55-70	yell & red sh & some chan stone
70-85	light blue sh.
85-120	blue sh & very fine salty ss
120-140	fine white ss
140-145	med fine white ss getting coarser

WELL COMPLETION RECORD

Drilling Method: Rot. Circ.

Depth (from ground level), Ft. 139
Date Completed 8-21-87

Casing: Length, Ft. 129 ; Dia.In. 4
Wall Thickness, Inch 200# ; type PVC

Screen: Length, Ft. 10 Dia.In. 4
Type Keypt. wrp pvc , slot Size .030

Drop Pipe: Length, Ft. ____ Dia.In. ____

Water Level, Surface to top of water, Ft.:
Static 50 , Pumping ____

Yield: 25 + ggm, Measured ☒ , Est. ☐
Chlorination Completed Yes ☐ No ☐

The above information including "Log of Well" is a true record of the job performed by me.

Driller Bill Gibson
(Signed)

REMARKS Didn't go deeper for fear of getting into salt. NITRATE NITROGEN < 0.1 p.p.m. BACTERIOLOGICAL O.K.

Address ____


Date 10-26-87

DO NOT WRITE BELOW THIS DOUBLE LINE

Health Department forwarded copy of record to Nebraska Conservation and Survey Department for Scientific Record ☒

FORM 23-4

AS BUILT DRAWING OF INSTALLATION IN RELATION TO BUILDINGS, PROPERTY LINES, OTHER WELLS, AND SOURCES OF CONTAMINATION. INDICATE NORTH.



Call First.
Ernie wants to be there
when inspected

017

Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

REAL ESTATE TRANSFER/LOAN APPROVAL FORM

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECK PAYABLE TO: Lincoln-Lancaster County Health Department or LLCHD

☐ Enclosed is $150.00. Allow two weeks for processing. Incomplete information will delay processing.

☒ Evaluation of the Individual Water System ☒ Evaluation of the Sewage Disposal System

Legal Description of Property: Street Address 2317 S. Coddington was 113
Twp 10N Range 6E Section 33 1/4 ___ 1/4 ___ Block ___ Lot 140 Addition ___
Directions to Property between South St. & Van Dorn

Location of Well South of house Tap Location: Inside ☒ or Outside ☒
Location of Sewage System West of house Year Installed ___

	NAME	ADDRESS	PHONE
Present Owner:	Ernest Gaube	2317 S. Coddington Lincoln NE 68522	477-7019
Tenant/Buyer:	Richard Carter	3920 A Street Lincoln NE 68510	483-5858
Return to:	Ernest Gaube	2317 S. Coddington Lincoln NE 68522	477-7019

Signature of Applicant Ernest Gaube Address 2317 S. Coddington Lincoln NE 68522 Date 3/27/95

HEALTH DEPARTMENT USE ONLY

Date Received 3/27/95 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--By Jerrold C. Hood **DATE:** 3/28/95

WATER SYSTEM:	Approved	Disapproved	**SEWAGE SYSTEM**	**Additional Site Visits**
Construction	☒	☐	Approved ☐	Date ___/___/___ by ___
Bacteria	☒ 0 /ml	☐ ___ /ml	Provisional ☐	Date ___/___/___ by ___
Nitrate	☒ <0.1 ppm	☐ ___ ppm	Disapproved ☒	Date ___/___/___ by ___

Comments: NEED TALLER FENCE AROUND LAGOON. NEW LOCKED STANDARD MAN GATE FOR GATE. NEED WARNING SIGNS AROUND FENCE. WELL ALMOST IS IN A DEPRESSION SHOULD BE SOME FILLING AROUND IT. See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ **SEWAGE DISPOSAL SYSTEM** Approved: ☒ Provisional Approval: ☐

Approved by Jerrold C. Hood R.E.H.S. Date 4/21/95

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.