FILE #2539

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

| | |
|---|---|
| INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION | FEBRUARY 1 1988 |
| TYPE OF LICENSE OR PERMIT | THIS LICENSE OR PERMIT EXPIRES |
| MELVIN ELLIS 2422 LYNN | LINCOLN, NE 68503 |
| LICENSEE OR PERMITTEE | ADDRESS |
| T11N; R6E; Sec SW¼ 23; 21 3/4 Acres; 400 McKelvie Rd., Lincoln | |
| NAME OF ESTABLISHMENT, IF ANY | ADDRESS |

REMARKS: NON TRANSFERABLE NEW CONSTRUCTION

| PERMIT | ACCOUNTING NUMBER | TOTAL |
|---|---|---|
| $ 60.00 | 018754 | $ 60.00 |

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH

ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

**A**

FILING FEE: $ 60.00

FILE NO. 2539

DATE: 8/3/87

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 11 NORTH; Range 6E; Section S.W. 1/4 23;
   Block _____: Lot _____: Addition 2 1/4 ACRES
   Street Address 400 McKELVIE RD LIN. 68531

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 2. Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: NONE ft.

Mum Elias
Signature of Applicant (Owner or Lessee)

2422 LYNN LIN. 68503
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 8/3/87. Date Frwd. 8/3/87. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Nodd

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. 8/4/87. Date Frwd. 8/4/87. ACTION: Approved ☐ Disapproved ☒ Signature: Gary M. Sherwood

3. City or County Engineer: Date Rec'd. 8-3-87. Date Frwd. 8-3-87. ACTION: Approved ☒ Disapproved ☐ Signature: Ford D. Mapham

REMARKS OR REASONS FOR DISAPPROVAL HAS WELL PERMIT

Site Visits:
Date: 9-15-87 by: rm need drawing
Date: _____ by: _____
Date: _____ by: _____


INSTALLATION FINAL WRITTEN APPROVAL
Date: _____ By: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 23-43

7539

| | 11:15 | 11:45 | 12:15 | 12:45 | 1:15 | 1:45 | 2:15 | 2:45 | 3:15 |
|---|---|---|---|---|---|---|---|---|---|
| 1 | 1" | 5/8" | 5/8" | 3/4" | 3/4" | 3/4" | 7/8" | 3/4" | 1" |
| 2 | 1/4" | 1/4" | 1/4" | 1/4" | 1/4" | 1/4" | 3/8" | 1/4 | 1/4" |
| 3 | 1/2" | 1/2" | 1/2" | 5/8" | 5/8" | 5/8" | 3/4" | 5/8 | 5/8" |
| 4 | 3/4" | 5/8" | 5/8" | 3/4" | 3/4" | 3/4" | 7/8" | 3/4 | 1" |
| 5 | 1/4" | 3/8" | 1/4" | 1/2" | 3/8" | 3/8" | 3/8" | 3/8 | 3/8" |
| 6 | 3/4" | 5/8" | 5/8" | 3/4" | 5/8" | 5/8" | 5/8" | 5/8 | 3/4" |




44 min/in

199' if perforated in 3' wide trench.

4/21/87

J.C.H.

Morrill Clay Loam

PART OF SOUTH WEST
1/4 SECTION 23,
TOWNSHIP 11 NORTH
RANGE 6
EAST OF THE SIXTH P.M.
LAN. COU. NE.