LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

Division of Environmental Health
2200 St. Marys Ave Lincoln, NE 68502 (402) 471-8000

NON TRANSFERABLE

PERMIT
SEWAGE INSTALLATION

No. 90380061301

Issued 07/13/90
Expires 07/13/91

ESTABLISHMENT
MARY POLINKA
T11N R6E SEC 26 QTR NE
6101 N 27 STREET

FEES: Permit 018754 $150.00

Total $150.00

PERMITTEE MARY POLINKA
6101 N 27 ST
LINCOLN NE 68521

Issued By COUNTY HEALTH

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

DATE	AMOUNT
7/17/90	PAID

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 471-7800

A

FILING FEE: $_____

FILE NO._____

DATE: 7/13/90

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 11N ; Range 6E ; Section 26 ; NE¼ of SW¼ of NE¼ of SW¼
   Block_____ : Lot_____ : Addition_____
   Street Address 8101 N 7
2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3 . Describe_____
3. Type of Individual Sewage Disposal System: Septic Tank ☐ ; Other ☒ LAGOON
4. Distance to public sewer: 2 ft.

Mary Pohlika for Rebecca
Signature of Applicant (Owner or Lessee)

6101 N 27th
Address

(Do not write below this double line) 467-1392

1. Health Department: Date Rec'd. 7/13/90. Date Frwd. 7/13/90. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood
2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. 7-13-90. Date Frwd. 8-13-90. ACTION: Approved ☒ Disapproved ☐ Signature: Paul Bauma
3. City or County Engineer: Date Rec'd. 7-13-90. Date Frwd. 7-13-90. ACTION: Approved ☒ Disapproved ☐ Signature: R.D. Mohr

REMARKS OR REASONS FOR DISAPPROVAL LAGOON MUST BE SEALED

Site Visits:
Date: July-90 by: rvm - must remove sod before building up dike
Date: Nov-5-90 by: DMM - inside slope too steep.
Date:_____ by:_____

INSTALLATION FINAL WRITTEN APPROVAL
Date:_____ By:_____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 23-43

Rebecca L. Polivka
8101 N. 7th Street
Lincoln, NE 68521

NE1/4 of SW1/4 of NE1/4 of SW1/4 S26,T11N,R6, E. of 6th p.m.

Lagoon dimensions:

13'
43'
4½'
3-1 slope

