FILE NO. 362

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION

TYPE OF LICENSE OR PERMIT

April 30, 1974

THIS LICENSE OR PERMIT EXPIRES

Richard Suhr

LICENSEE OR PERMITTEE

1027 South 31st St.

ADDRESS

T10N; R7E; Ne 1/4 of Section 25; Lot 14.

NAME OF ESTABLISHMENT, IF ANY

LEGAL DESCRIPTION

ADDRESS

REMARKS:

NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
624-1535 110.15	110.16	148.14	6-2

SERIAL NO.	DATE	AMOUNT

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-32(67) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 362

DATE: 29 OCT 73

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: LOT 14 IN THE (NE¼) OF SECTION 25 TOWNSHIP 10 NORTH, RANGE 7 EAST OF THE 6TH PM LANCASTER COUNTY
Twp. 10; Range 7; Section (NE¼) 25
Block ____; Lot 14; Addition ____;
Street Address ____.

2. Property Use: Residential ____ [✓]; Commercial ____ [ ]
No. of Bed Rooms 3 Describe: ____
Other Use ____ [ ]
Describe: ____

3. Type of Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Richard Lubs
Signature of Applicant (owner or lessee)

1027 So 31 ST LINCOLN,
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: ____
Filing Fee: $ 30.00

2. Date Site Clearance 12-3-73

3. Site Visits:
Date: 12-3-73 by: jw
Date: ____ by: ____
Date: ____ by: ____

4. Date: Approved [X]; Disapproved [ ]: 10/29/73
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified: ____
Date Issued: ____ Serial ____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 12-3-73 by: jw

FORM HD-30(67) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 362

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: LOT 14 IN THE (NE¼) OF SECTION 25, TOWNSHIP 10 NORTH, RANGE 7, EAST OF THE 6TH PM LANCASTER COUNTY
Twp. 10; Range 7; Section (NE¼) 25
Block ____; Lot 14; Addition _____;
Street Address _____.

2. Property Use: Residential _____ ☑; Commercial _____ ☐
No. of Bedrooms 3. Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Distance to public sewer: 11,000 ft.

Richard Lahr
Signature of Applicant (owner) or lessee)

1027 So 31st Lincoln
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/29/73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. _____. Signature: Jerold C. Hood

2. Supt. Bldg. Insp.: Date Rec'd. 10-30-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 10-30-73. Signature: Chas Leal by Bob Hummer

3. City Engineer: Date Rec'd. 10-30-73. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 10-30-73. Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☒ Disapproved ☐

Date Applicant Notified: 12-3-73 Signature James Wewerka

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 362

PROPERTY WHERE SOIL TESTED: 2⅓ MI. E OF 84TH & O ST & ½ MI SOUTH

Owner: Richard Lahr

Location: Township 25-10-7 LOT 14, N.E.
Section & ¼ Sect. _____

Address 1027 SO "31" ST

Property Dimensions: 834.84 ft. x 313.06 ft.
Area: 6.0 acres. (Attach sketch of property showing hole location).

Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☐; Sandy Clay ☒

Dates of Tests: aug 21 73 to aug 22-73. Weather: Precip. 0 Temp. 95° F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings					Results		
		Start		End		Start			End				
Hole No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36"	8/21	6 PM	8/22	6 PM	8/22	6 PM	12"	7:15 PM	3	30	2½	
2	"	"	"	"	"	"	"	"	"	4	"	2	
3	"	"	"	"	"	"	"	"	"	6½	"	1½	
4	"	"	"	"	"	"	"	"	"	3½	"	2	
5	"	"	"	"	"	"	"	"	"	4	"	2	
6	"	"	"	"	"	"	"	"	"	6	"	2	

Robert D Johnson
Signature of Person Conducting Test

Address 426 NW 13TH
Phone: 432 3545

Sum of Percolation Rates _____
Average of Rates: _____
Mean of Rates: _____

(Do not write below this line)


REVIEWING ACTION

REMARKS: _____


Approved Percolation Rate(s)
A. 15 min./inch
B. _____ min./inch
C. _____ min./inch


DATE: 12-3-73

Gerrald C. Hook
Signature of Reviewing Official


834.84
N
LOCATION OF TESTS
W.
E.
313'
HOUSE
ROAD
SHED
WELL
80'
S.
DRIVE
324'

TRENCH LATERAL




W
313'
834'
LOT LINE
LOT LINE
80'
LATERAL
80'
LATERAL
DISTRIBUTION BOX
SEPTIC TANK
100'
100'
90'
80'
WELL
80'
HOUSE
E
N

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 362

SPECIFICATIONS

DATE: 29 OCT 73


A. BUILDING SEWER:
1. Material CONCRETE; Diameter 5 in.
2. Distance above basement floor ___ in.; or below basement floor 32 in.
3. Distance between dwelling and septic tank 90 ft.
4. Number of clean-outs ___.
5. Distances To:
   Well or Suction Line 60 ft.;
   Stream 5000 ft.; Pressure Line ___ ft.;
   Property Line 50 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material CONCRETE; No. of compartments ___.
2. Capacity 1000 gals.; Liquid depth 47 in.
3. Factory Built: Yes [✓] (Company PRE-CAST STEP CO.)
   No [ ]
4. Manholes: Over Inlet; diam. ___ in.
   Over Outlet; diam. ___ in.
   Below Grade ___ in.
5. Inlet: Baffle [ ]; or Tee [ ]
6. Outlet: Baffle [ ]; or Tee [ ]
   Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade ___ in.
8. Distances To:
   Well or Suction Line 100 ft.;
   Stream 5000 ft.; Pressure Line ___ ft.;
   Property Line 100 ft.


C. DISTRICTION BOX
1. Material CONCRETE; No. available outlets ___.
2. Factory Built: Yes [✓], (Company PRE-CAST)
   No [ ]
3. Dimension: Length ___ in.; Width 36 in.
   Depth ___ in.
4. Distance from Septic Tank ___ ft.
5. Serial Distribution: Yes [ ], No [ ]
   (If yes, show detailed plans.)

D. ABSORPTION FIELD: (Provide drawings.)
1. Type: ___
2. Lateral Lines: Depth below grade 36 in.
   Number 2; Length of each line 80 ft
   Total length of Laterals [redacted] ft.; 190
   Slope 12 in/100 ft. Diameter of pipe 5 in.; Shape ROUND
   Material: concrete [✓]; fiber asbestos [ ]; clay [ ]; other ___
   Distance between lateral lines ___ ft.
3. Trench Dimensions: Depth 36 in.; Width 36 in.
4. Filter Material: ___.
   Depth of material from trench bottom ___ in.
5. Distances To:
   Well or Suction Line ___ ft.;
   Stream ___ ft.; Pressure Line ___ ft.
   Property Line ___ ft.
6. Percolation Rate: 15 minutes/inch

TYPICAL SKETCHES



Signature of Applicant



12-3-73
jw

4' wide
3' deep

N

Needs cleanout; at least one