LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1201-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

April 24, 1978 — THIS PERMIT EXPIRES

Roy Nifoussi — ISSUED TO

Rural Route 1, Raymond, NE — ADDRESS

T11N, R6E, Section 5 — LEGAL DESCRIPTION

REMARKS: NON-TRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-40(73) REQUEST FOR SITE CLEARANCE FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐

County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1201-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: _____

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

SEE ATTACHED

1. Legal description of property: Twp. 11N ; Range 6E ; Section 5
   Block _____; Lot _____; Addition _____
   Street Address _____

2. Property Use: Residential _____ ☐ ; Commercial _____ ☐
   No. of Bedrooms 3 . Describe: _____
   Other Use _____ ☐
   Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Roy Nilsson
Signature of Applicant (Owner or Lessee)

RR 1 Raymond Ne.
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 10/21/77. ACTION: Approved ☒ Disapproved ☐
   Date Frwd. 10/21/77. Signature: Jerrold E. Hood

2. Supt. Bldg. Insp.: Date Rec'd. _____. ACTION: Approved ☐ Disapproved ☐
   Date Frwd. _____. Signature: _____

3. City or County Engineer: Date Rec'd. 10-24-77. ACTION: Approved ☒ Disapproved ☐
   Date Frwd. 10-24-77. Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

Wesley W Howsley

FORM HD-42(73) APPLICATION FOR PERMIT TO CONSTRUCT INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1201-C

DATE: _____

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with appropriate Ordinance or Resolution, as described in this application and the annexed forms attached hereto. SEE ATTACHED

1. Legal description of property: Twp. 11N ; Range 6E ; Section 5 ; Block _____ ; Lot _____ ; Addition _____.
Street Address _____.

2. Property Use: Residential _____ ☐ Commercial _____ ☐
No. of Bedrooms 3 Describe: _____
Other Use _____
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Plans and Specifications of Proposed System. (See FORM HD-45(73) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-43(73) SOIL ABSORPTION TEST DATA REPORT, attached hereto).

Roy Nilonsi
Signature of Applicant (owner or lessee)

R.R. 1 Raymond
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd; _____
Filing Fee: $ 30.00

2. Site Visits:
Date: 11-2-77 by: jpv
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐ 10/27/77
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 11-2-77 by: James Overbeck

FORM HD-43 (73) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 474-1541)

FILE NO. 1301-C

PROPERTY WHERE SOIL TESTED:
Location: Township _____ : Range _____
Section & ¼ Sect. _____
Property Dimensions: 305 ft. x 527 ft.
Area: 4 acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ; Silty Clay Loam ; Sandy Loam
Silty Loam ; Clay Loam ; Sandy Clay

Owner: Roy A. Nifoussi
Address: R.R.1, Raymond, Ne

Dates of Tests: 10-15-77 to 10-16-77. Weather: Precip. 0 Temp. ____

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Date (Mo. Day)	Time (Hr. Min.)	Water Level (in.)	Time (Hr. Min.)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36	10-15	4:10 pm	10-16	3:20	10-16	3:20	6"	6:58	4¾"	30	1¼	
2	36	10-15	4:13 pm	10-16		10-16							
3	36	10-15	4:17 pm	10-16	3:25	10-16	3:25	6"	7:00	5¼"	30	¾	
4	30	10-15	4:20 pm	10-16		10-16							
5	36	10-15	4:25 pm	10-16	3:28	10-16	3:28	6"	7:03	5"	30	1	
6	30	10-15	4:30 pm	10-16	3:30	10-16	3:30	6½"	7:05	5¼"	30	1¼	

Sum of Percolation Rates: ____
Average of Rates: ____
Mean of Rates: ____

Roy A. Nifoussi
Signature of Person Conducting Test

Address R.R.1 Raymond
Phone 783-2859

(Do not write below this line)

REVIEWING ACTION

REMARKS: Could be either Morril Clay Loam or Kennebec Silt Loam. (L.C.S.S.)

DATE: October 21, 1977

Approved Percolation Rate (a)
A. 28 min./inch
B. ____ min./inch
C. ____ min./inch

Jerrold C. Hood
Signature of Reviewing Official

FORM HD- 45(73) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM

(Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1201-C

SPECIFICATIONS

DATE: _____


A. BUILDING SEWER:
1. Material _____; Diameter ____ in.
2. Distance above basement floor ____in.; or below basement floor ____in.
3. Distance between dwelling and septic tank ____ft.
4. Number of clean-outs _____.
5. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material _____; No. of compartments _____.
2. Capacity 1000 gals.; Liquid depth ____in.
3. Factory Built: Yes ☐ (Company _____)
No ☐
4. Manholes: Over Inlet; diam. ____in.
Over Outlet; diam. ___in.
Below Grade _____in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
Depth of outlet below inlet ___in.
7. Depth of top of tank below finished grade ____in.
8. Distances To:
Well or Suction Line ____ft.;
Stream ____ft.; Pressure Line ____ft.;
Property Line ____ft.

C. DISTRIBUTION BOX
1. Material _____; No. available outlets _____.
2. Factory Built: Yes ☐, (Company _____) No ☐
3. Dimension: Length ____in.; Width ___in. Depth ____in.
4. Distance from Septic Tank ____ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)


D. ABSORPTION FIELD: (Provide drawings.)
1. Type: _____
2. Lateral Lines: Depth below grade ___in. Number ____; Length of each line ___ft Total length of Laterals 242 or 118 ft.; Slope ____in/100 ft. Diameter of pipe ____ in.; Shape _____
Material: concrete ☐; fiber asbestos ☐; clay ☐; other _____
Distance between lateral lines ____ft.
3. Trench Dimensions: Depth ___in.; Width 36 OR 48 in.
4. Filter Material: _____.
Depth of material from trench bottom _____in.
5. Distances To:
Well or Suction Line ____ft.;
Stream _____ft.; Pressure Line ____ft.
Property Line ____ft.
6. Percolation Rate: _____minutes/inch

TYPICAL SKETCHES



_____
Signature of Applicant

House Located
in Rural Raymond



Roy Nifoussi
2340 Forest
Crete, Ne. 68333
826-2989
473-6364 (work)

Loan Company:
Frank Vogt
Commercial Federal
17 & South
Lincoln, Ne.

Referring to the Northwest corner of Section Five (5), Township Eleven (11) North, Range Six (6) East of the 6th P.M., Lancaster County, Nebraska. Thence in an Easterly direction along the North line of the Northwest Quarter (1/4) of said Section Five (5) a distance of Five Hundred Eighty and No Tenths (580.0) feet. Thence right 90°00'00" in a Southerly direction perpendicular to the North line of the Northwest Quarter (1/4) of said Section Five (5) a distance of Fifty and No Tenths (50.0) feet to a point on the Southerly Fifty (50) foot Right-Of-Way line of Raymond Road and the Point of Beginning. Thence continuing in a Southerly direction along the last described course a distance of Five Hundred Seventy-one and Twenty-eight Hundredths (571.28) feet. Thence left 90°00'00" in an Easterly direction parallel to, and Six Hundred Twenty-one and Twenty-eight Hundredths (621.28) feet South of the North line of the Northwest Quarter (1/4) of said Section Five (5) a distance of Three Hundred Five and No Tenths (305.0) feet. Thence left 90°00'00" in a Northerly direction perpendicular to the North line of the Northwest Quarter (1/4) of said Section Five (5) a distance of Five Hundred Seventy-one and Twenty-eight Hundredths (571.28) feet to a point on the Southerly Fifty (50) foot Right-Of-Way line of Raymond Road. Thence left 90°00'00" in a Westerly direction parallel to and Fifty and No Tenths (50.0) feet South of the North line of the Northwest Quarter (1/4) of said Section Five (5) said line being also the Southerly Fifty (50) foot Right-Of-Way line of Raymond Road a distance of Three Hundred Five and No Tenths (305.0) feet to the Point of Beginning and containing a calculated area of Four and No Tenths (4.0) Acres more or less.