FILE #2249

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

FEBRUARY 28, 1986
THIS LICENSE OR PERMIT EXPIRES

CLYDE SOUTHWICK, BIG CLYDE SANITATION, BOX 483
LICENSEE OR PERMITTEE

WALTON, NE 68461
ADDRESS

T10; R7E; Sec 26; Bk 7; Lot 2; Hillcrest Heights
NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON TRANSFERABLE ALTER, EXTEND OR REPAIR

| PERMIT | ACCOUNTING NUMBER | TOTAL |
|---|---|---|
| $ 30.00 | 018606 | $ 30.00 |

Valid Receipt Only if Machine Receipted In This Space

Serial No. Date and Amount

APPLICATION

HEALTH
ISSUING OFFICER OR DEPARTMENT

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 [X]
County Resolution No. 2832 [ ]

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. 2249

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 5-9-85

The undersigned hereby applies for a permit to ALTER [X], EXTEND [ ], or REPAIR [X] an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10N ; Range 7E ; Section 26 ;
Block 7 ; Lot 2 ; Addition HILLCREST HEIGHTS
Street Address 700 Hillcrest Drive

2. Property Use: Residential [X]; Commercial [ ]
No. Bedrooms 3
Describe
Other Use [ ]
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank [X]; Other [ ]

4. Description of proposed alteration, extension or repair: Add on More Lateral

5. Work to be done by: Owner [ ] ; or Contractor [X], Big Clyde Sanitation
Contractor's Name

6. Estimated cost of project: Over $400

a. Materials $
b. Labor $
c. Other $
TOTAL $

Big Clyde Sanitation Clyde P Southwick
Signature of Applicant (owner or lessee)

Box 483 Walton, Nebr.
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00

2. Site Visits:
Date: Early Summer by: mm
Date: by:
Date: by:

3. Date: Approved [X]; Disapproved [ ]
by: Jerrold E. Hook

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: Aug-30-85 by: Ron Marquardt


N
Old Lateral
House
Tank
Pump Location
Road
100 ft Old Lateral
Deaded 1969 Lateral
W
E
100 ft 1/4 Moon Corr. Glass
2 on 12" Cement Blocks
New Lateral 32 ton Rd Gravel
Lift Station
S

FILE NO. 120

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

February 19, 1969
THIS LICENSE OR PERMIT EXPIRES

Bill Sorensen
LICENSEE OR PERMITTEE

500 Hillcrest Drive
ADDRESS

T 10N; R 7E; Section 26; Blk. 7; Lot 2; Hillcrest Heights Addition
NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: Non-Transferable

| PERMIT | INSPECTION FEE | OCCUPATION TAX | LICENSE | TOTAL |
|---|---|---|---|---|
| $30.00 | $ | $ | $ | $ 30.00 |

| ACCOUNTING NO. | ACCOUNTING NO. | ACCOUNTING NO. | CODE |
|---|---|---|---|
| 143110.1535 | 110.16 | 148.14 | 6-2 |

| SERIAL NO. | DATE | AMOUNT |
|---|---|---|
| 16896 NB208 | | 30.00 |

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-31(67) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 120

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 8/15/69

The undersigned hereby applies for a permit to ALTER [✓], EXTEND [✓], or REPAIR [✓] an existing Individual Sewage Disposal System, in conformance with Lincoln City Ordinance No. 9150, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10N; Range 7E; Section 26;
Block 7; Lot 2; Addition HILLCREST HEIGHTS
Street Address 500 East Hillcrest Dr.

2. Property Use: Residential [✓]; Commercial [ ]
No. Bedrooms 2
Describe
Other Use [ ]
Describe

3. Type of existing Individual Sewage Disposal System: Septic Tank [✓]; Other [ ]

4. Description of proposed alteration, extension or repair: Add 100' of lateral - 300 sq. ft. screened bed moss

5. Work to be done by: Owner [ ]; or Contractor [✓], Harry Sintek
Contractor's Name

6. Estimated cost of project:

| | | |
|---|---|---|
| a. Materials | $ | |
| b. Labor | $ | |
| c. Other | $ | |
| TOTAL | $ | 470.00 |

Bill Sorensen
Signature of Applicant (owner or lessee)

500 Hillcrest Dr.
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd:
Filing Fee: $ 30.00


2. Date Site Clearance:

3. Site Visits:
Date: 8/15/69 by: KWC
Date: by:
Date: by:

4. Date: Approved [✓]; Disapproved [ ]
by:

5. BUREAU OF LICENSES & PERMITS
Date Notified:
Date Issued: Serial

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 8/19/69 by: L.C.H.


house
100' addition
6'
tree
100ft
existing
100ft
existing

Water Sampling Record #624 010405001 tdp

# Lincoln-Lancaster County Health Department

3140 "N" Street, Lincoln, Nebraska 68510 Phone: 441-8022

## REAL ESTATE TRANSFER/LOAN APPROVAL FORM

FOR PROPERTY IN **LANCASTER COUNTY** ONLY

#9038005 95 PID #17-26-206-002-000

This form must be completed and returned with payment to request a real estate transfer inspection. 4/1/01

**MAKE CHECK PAYABLE TO:** "Lincoln-Lancaster County Health Department" or "LLCHD"

☒ Enclosed is $200.00. Allow two weeks for processing. Incomplete information will delay processing.

LCR 987

Legal Description of Property: Street Address 700 E. HILLCREST DR.

Parcel ID 17 - 26 - 206 - 002 - 000 (i.e. 99-99-999-999-999)

Twp 10N Range 7E Section 26 1/4 ___ 1/4 ___ Block 7 Lot 2 Addition HILLCREST HTS. L.L.C.N.

Directions to Property FROM 84TH AND O ST., ½ MILE EAST, THEN SOUTH ON HILLCREST DRIVE APPROX ¼ MILE

Location of Well BACK YARD Tap Location: Inside ☐ Outside ☒

Location of Sewage System SEPTIC - FRONT YARD, LATERALS - FRONT & SOUTH Year Installed 1969

Site Hazards (dogs, etc.) NONE LATERALS ADDED 8/15/69 & IN 1985 ← ALSO A LIFT PUMP

| | NAME | ADDRESS | PHONE |
|---|---|---|---|
| Present Owner: | KAREN LINDSAY | 700 E. HILLCREST DR. LINCOLN, NE 68520 | 483 6687 |
| Tenant/Buyer: | MIKE GERDES | 5023 N. 20TH LINCOLN, NE 68521 | 477 5661 |
| Return to: | MIKE GERDES | 5023 N. 20TH LINCOLN, NE 68521 | 477 5661 (Fax) |

Signature of Applicant Michael D. Gerdes Address 5023 N. 20TH LINCOLN, NE 68521 Date 03/31/01

### HEALTH DEPARTMENT USE ONLY

**RECEIVED** Date 04/02/01 Amount 200.00 Check No. 2364 Initials LO

**DATA ENTRY** Date ___/___/___ Case No. ___ Initials ___

**PRELIMINARY STATUS--By** Gerald C. Hood **DATE:** 4/3/01

| **WATER SYSTEM:** | Approved | Disapproved |
|---|---|---|
| Construction | ☒ | ☐ |
| Bacteria | ☒ 0 /ml | ☐ ___ /ml |
| Nitrate | ☒ 0.1 ppm | ☐ ___ ppm |

| **SEWAGE SYSTEM** | |
|---|---|
| Approved | ☐ |
| Provisional | ☒ |
| Disapproved | ☐ |

**Additional Site Visits**

Date ___/___/___ by ___

Date ___/___/___ by ___

Date ___/___/___ by ___

**Comments:** PORTIONS OF THE SEPTIC SYSTEM WERE CONSTRUCTED PRIOR TO REGULATIONS AND INSPECTIONS HENCE APPROVAL IS PROVISIONAL. IF THE SEPTIC TANK HAS NOT BEEN PUMPED RECENTLY IT SHOULD BE CHECKED TO SEE IF IT IS NEEDED. INSPECTION DOES NOT INCLUDE THE MECHANICAL OPERABILITY OF THE SEWAGE LIFT PUMP. ☐ See Attached Letter

**FINAL STATUS**

**WATER SYSTEM:** Approved ☒ **SEWAGE DISPOSAL SYSTEM:** Approved ☐ Provisional Approval ☒

Approved by Gerald C. Hood R.E.H.S. Date 4/4/01

Approval or disapproval is based on State and local standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operations.

White - Applicant after approval Yellow - Environmental Health Pink - Business Office

Revised/Reprint: 9-00