LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 ST. MARYS
LINCOLN, NEBRASKA 68502

FILE NO. 1923-C

INDIVIDUAL SEWAGE SYSTME CONSTRUCTION — TYPE OF PERMIT

MARCH 24, 1983 — THIS PERMIT EXPIRES

DELBERT EICKHOFF ROUTE #3 — ISSUED TO / ADDRESS

T11N, R7E, SECTION SW¼ 11 — LEGAL DESCRIPTION

REMARKS: NONTRANSFERABLE NEW

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 60.00	$	$	$ 60.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

HEALTH

ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 60.00

FILE NO. 1923-C

DATE: _____

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: SW 1/4 Twp. 11 North; Range 7E; Section 11;
   Block _____: Lot _____: Addition _____
   Street Address _____

2. Property Use: Residential ☐ ; Commercial ☐ Other Use ☒
   No. of Bedrooms _____. Describe Storage building

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: _____ ft.

Delbert Eichhoff
Signature of Applicant (Owner or Lessee)

RR # 3
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 9/24/82. Date Frwd. 9/24/82. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. _____. Date Frwd. _____. ACTION: Approved ☒ Disapproved ☐ Signature: Gary Sherwood

3. City or County Engineer: Date Rec'd. 9/24/82. Date Frwd. 9/24/82. ACTION: Approved ☑ Disapproved ☑ Signature: Larry V. Worrell

REMARKS OR REASONS FOR DISAPPROVAL Subject to plmb permit and inspections
Except

Site Visits:
Date: 9-30-82 by: JMN
Date: _____ by: _____
Date: _____ by: _____

INSTALLATION FINAL WRITTEN APPROVAL
Date: 10-27-82 By: John Nelson

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. _____

Indicate on sketch if residence and ~~well are exisiting or proposed.~~



WAVERLY RD.

South lateral had too much slope - ~~cut~~ it 30' short & add it to north lateral to get the present system

REVIEWING ACTION

Remarks: _____

Date: September 24, 1982

Minimum Design Requirement
1. Capacity of Septic Tank 1000 gals.
2. Total Length of Laterals 100 ft.
3. With a Trench Width of 4' in.
4. Total Area of Lateral needed ____ sq.ft.

Jerrold C. Hood
Signature of Reviewing Official