LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Lincoln, NE 68502-3785 (402) 471-8000

NON TRANSFERABLE

PERMIT

Permit
SEWAGE SYSTEM REPAIR

No. 92390029401

Issued 08/26/92
Expires 02/26/93
Revenue Code 18754

Establishment
RALPH YOUNG
T9N R7E SEC 18
AL LARSON BLK 2 LOT 4

FEES: $50.00

TOTAL $50.00

Permittee
RALPH YOUNG
1600 DIXIE TR
LINCOLN NE 68527

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO._____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 8-24-92

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 8N ; Range 7E ; Section 18 ;
Block 2 ; Lot 4 ; Addition AL LARSON SUB SAT-
Street Address 1600 DIXIE TRAIL

2. Property Use: Residential ACREAGE ☒; Commercial _____ ☐
No. Bedrooms _____ Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: VACATE EXISTING TANK AND INSTALL A WASTE STABILIZATION POND IN NE CORNER OF PROPERTY

5. Work to be done by: Owner ☐ ; or Contractor ☒ ; HAROLD NORMAN NORMAN PLUMBING
Contractor's Name

6. Estimated cost of project:

a. Materials	$_____
b. Labor	$_____
c. Other	$_____
TOTAL	$2000

Ralph D Young (owner)
Signature of Applicant (owner or lessee)

1600 DIXIE TRAIL LINCOLN NE
Address

(Do not write below this line)

REVIEWING ACTION


1. Date Rec'd: _____
Filing Fee: $ 50.00


2. Site Visits:
Date: 9-15-92 by: RM need fence (corrected)
Date: 9-28-92 by: RM fence up.
Date: _____ by: _____

3. Date: Approved ☒ ; Disapproved ☐
by: Jerrold E. Wood


4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 9-15-92 by: RM

NEBRASKA TITLE COMPANY
Ray Frohn Abstract Company
100 Court House Plaza
633 South 9th
Lincoln, Nebraska 68508
(402) 476-8818
FAX 476-0635





Capital City Trenching
9-15-92


SUBDIVISION
West
North
East
South
"Trude" Schomer
9
Steve & Betty Jo Dagley
3
Harry & Nadine Schomer
4
5
2
Del & Wanda Dagley
1
5' UTILITY EASEMENT
Ron & Glenva Stoddard
10
Larry & Barb Marquis
9
BLOCK #1
Dan Roth
11
Terry & Dyann Otero
8
Roger & Kimberly Swanson
7
Dick & Betty Mendoza
6
Stub & Shirley Seng
4
Robert & Pam Fox
1
Stan & Jane Meyer
WENZEL
Bob & Ginger Hartshorn
5
Dick & Vicki Stephenson
2
Jean & Hermy Schemik
1
Walter & June Williamson
2
William & Joyce Ross
4
BLOCK #2
Bob & Carol Klucas
3
60' set back
BLOCK #4
Gary & Jan Claussen
8
Marvin & Lou Rosen
7
Edgar & Vickie Weymire
6
Gordy & Bernie Hegal
5
Dale & Darlene Stunkel
4
BLOCK #3
Steve & Carol Anderson
5
Ralph & Lola Young
4
80' Set Back
Holdrege

CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

FILE NO. 59

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — January 3, 1968

TYPE OF LICENSE OR PERMIT — THIS LICENSE OR PERMIT EXPIRES

Donald Magee for Charles L. Seng. — 6331 Burlington

LICENSEE OR PERMITTEE — ADDRESS

T 10N; R 8N; Sec. 18; Blk. 2; Lot 4; Al Larson Addition

NAME OF ESTABLISHMENT, IF ANY — ADDRESS

REMARKS: Non-Transferable

PERMIT	INSPECTION FEE	OCCUPATION TAX	LICENSE	TOTAL
$ 30.00	$	$	$	$ 30.00

ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
143-1535	10.0116	24.0114	6-2

SERIAL NO.	DATE	AMOUNT
13862	JUL 3 '68	30.00 - CK

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

INTER-DEPARTMENT COMMUNICATION

TO Charlie Seale

DEPARTMENT Building Inspection

ATTENTION

CARBONS TO

DATE July 3, 1968

FROM Jerrold C. Hood

DEPARTMENT Health

SUBJECT Individual Sewage System Construction
FILE NO. 59
(Donald Magee for Charles L. Seng

The application and plans have been reviewed and approved for the construction of an individual sewage system on property legally described as:

T 10N; R 8N; Sec. 18; Blk. 2; Lot 4; Al Larson Addition

Jerrold C. Hood, R.S., Chief
General Sanitation Section
Division of Environmental Health

JCH:ls

FORM HD-30(67) REQUEST FOR SITE CLEARANCE : INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 59

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby requests SITE CLEARANCE to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described herein:

1. Legal description of property: Twp. 10; Range 8 E; Section 18;
Block 2; Lot 4; Addition Carlson
Street Address _____.

2. Property Use: Residential _____ ☑; Commercial _____ ☐
No. of Bedrooms 3. Describe: _____
Other Use _____ ☐
Describe: _____

3. Type of Individual Sewage Disposal System: Septic Tank ☑; Other ☐

4. Distance to public sewer: _____ ft.

Donald Magee for Charles L. Seng
Signature of Applicant (owner or lessee)

6331 Burlington
Address

(Do not write below this double line)

REVIEWING ACTION

1. Health Department: Date Rec'd. 7/2/68. ACTION: Approved ☒ Disapproved ☐
Date Frwd. 7/3/68. Signature: Jerrold C. Wood

2. Supt. Bldg. Insp.: Date Rec'd. _____. ACTION: Approved ☑ Disapproved ☐
Date Frwd. _____. Signature: Chas Seals By CS

3. City Engineer: Date Rec'd. _____. ACTION: Approved ☐ Disapproved ☑
Date Frwd. 1-3-68. Signature: [illegible]

REMARKS OR REASONS FOR DISAPPROVAL _____

FINAL ACTION ON SITE CLEARANCE: Approved ☐ Disapproved ☐

Date Applicant Notified: _____ Signature _____

FORM HD-32(67) APPLICATION FOR PERMIT
TO CONSTRUCT INDIVIDUAL SEWAGE
DISPOSAL SYSTEM
City Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 59

DATE: 1 July 68

TO: Director of Health
Lincoln-Lancaster County Health Dept.

The undersigned hereby applies for a permit to construct an Individual Sewage Disposal System in conformance with Lincoln City Ordinance No. 9150, as described in this application and the annexed forms attached hereto.

1. Legal description of property: Twp. 10 ; Range 6 W ; Section 18 ;
Block 2 ; Lot 4 ; Addition Alderson
Street Address _____.

2. Property Use: Residential _____ [✓]; Commercial _____ [ ]
No. of Bed Rooms 3 Describe: _____
_____
Other Use _____ [ ]
Describe: _____
_____

3. Type of Individual Sewage Disposal System: Septic Tank [✓]; Other [ ]

4. Plans and Specifications of Proposed System. (See FORM HD-32a(67) PLANS & SPECIFICATIONS, SEWAGE DISPOSAL SYSTEM, attached hereto.)

5. Soil Absorption Properties. (See FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT, attached hereto.)

Donald Mayer for Charles L Long
Signature of Applicant (owner or lessee)

6331 Burlington
Address

(Do not write below double line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $_____. _____

2. Date Site Clearance _____

3. Site Visits:
Date: 7/23/68 by: L.C.H.
Date: _____ by: _____
Date: _____ by: _____

4. Date: Approved [X]; Disapproved [ ]: 7/2/68
by: Jerrold C. Hood

5. BUREAU OF LICENSES & PERMITS
Date Notified: _____
Date Issued: _____ Serial _____

6. INSTALLATION FINAL WRITTEN APPROVAL
Date: 7/23/68 by: Jerrold C. Hood

FORM HD-33(67) SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone 432-7611)

FILE NO. 59

PROPERTY WHERE SOIL TESTED:
Location: Township 10 R 8N
Section & ¼ Sect. 18
Property Dimensions: ____ft. x ____ ft.
Area: _____acres. (Attach sketch of property showing hole location).
Soil Type: Silty Clay ☐; Silty Clay Loam ☐; Sandy Loam ☐
Silty Loam ☐; Clay Loam ☑; Sandy Clay ☐

Owner: Charles Y Levy
Address 4932 Adams

Dates of Tests: 1 July to 2 July. Weather: Precip. None Temp. 80 F.

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
Hole No.	Hole Depth (in.)	Pre-Saturation Period Start Date (Mo. Day)	Start Time (Hr. Min.)	End Date (Mo. Day)	End Time (Hr. Min.)	Percolation Readings Start Date (Mo. Day)	Start Time (Hr. Min.)	Start Water Level (in.)	End Time (Hr. Min.)	End Water Level (in.)	Results Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./inch)
1	36	July 1	10:00	July 2	0800	0800	July 2	30	0814	29	14	1	14/1
2	36	July 1	10:00	July 2	0800	0800	July 2	30	0814	24	14	1	14/1

Sum of Percolation Rates
Average of Rates: 14/1
Mean of Rates:

Signature of Person Conducting Test

Address Donald Magee
Phone: 488-8099

(Do not write below this line)

REVIEWING ACTION

REMARKS: _____

Approved Percolation Rate(s)
A. 14 min./inch
B. _____ min./inch
C. _____ min./inch

DATE: July 2, 1968

Jerrold C. Hood
Signature of Reviewing Official

FORM HD-32a(67) PLANS & SPECIFICATIONS
SEWAGE DISPOSAL SYSTEM
(Annex to Application)
Ordinance No. 9150

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502 (Phone: 432-7611)

FILE NO. 59

SPECIFICATIONS

DATE: 1 July 68


A. BUILDING SEWER:
1. Material Clay; Diameter 4 in.
2. Distance above basement floor ___ in.; or below basement floor 12 in.
3. Distance between dwelling and septic tank 30 ft.
4. Number of clean-outs ___.
5. Distances To:
   Well or Suction Line 100 ft.;
   Stream ___ ft.; Pressure Line ___ ft.;
   Property Line 120 ft.

B. SEPTIC TANK (Provide construction drawings.)
1. Material Timber & Glass; No. of compartments 1.
2. Capacity 1000 gals.; Liquid depth 48 in.
3. Factory Built: Yes ☐ (Company Corrugated) No ☐
4. Manholes: Over Inlet; diam. 16 in.
   Over Outlet; diam. ___ in.
   Below Grade 18 in.
5. Inlet: Baffle ☐; or Tee ☐
6. Outlet: Baffle ☐; or Tee ☐
   Depth of outlet below inlet ___ in.
7. Depth of top of tank below finished grade 18 in.
8. Distances To:
   Well or Suction Line 100 ft.;
   Stream ___ ft.; Pressure Line ___ ft.;
   Property Line 120 ft.

C. DISTRIBUTION BOX
1. Material Concrete; No. available outlets 5.
2. Factory Built: Yes ☐, (Company ___) No ☐
3. Dimension: Length 13 in.; Width 11 in. Depth 8 in.
4. Distance from Septic Tank 8 ft.
5. Serial Distribution: Yes ☐, No ☐ (If yes, show detailed plans.)


D. ABSORPTION FIELD: (Provide drawings.)
1. Type: Half Moon
2. Lateral Lines: Depth below grade 20 in. Number 2; Length of each line 75 ft Total length of Laterals 145 ft.; Slope 2 in/100 ft. Diameter of pipe 6 in.; Shape Half Moon Material: concrete ☐; fiber ☐; asbestos ☐; clay ☐; other ___ Distance between lateral lines 20 ft.
3. Trench Dimensions: Depth 36 in.; Width 48 in.
4. Filter Material: Gravel. Depth of material from trench bottom 16 in.
5. Distances To:
   Well or Suction Line 100 ft.;
   Stream ___ ft.; Pressure Line ___ ft.
   Property Line 120 ft.
6. Percolation Rate: 14 minutes/inch

TYPICAL SKETCHES



SEPTIC TANK

Donald Moore for Charles J. Long
Signature of Applicant


E
N
S
W
HOUSE
15'10"
CLAY TILE
38'
45'
REDUCER
CAST IRON
5'
90'
55'
PROPERTY LINE