FILE NO. 1321

# CITY OF LINCOLN NEBRASKA

DEPARTMENT OF LICENSES AND PERMITS

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION
TYPE OF LICENSE OR PERMIT

November 23, 1978
THIS LICENSE OR PERMIT EXPIRES

Steven Dagley
LICENSEE OR PERMITTEE

Route 2, Lincoln, NE
ADDRESS

T10N, R8E, Section 18, Block 1, Lot 3, Addition Dagley Replat
NAME OF ESTABLISHMENT, IF ANY

ADDRESS

REMARKS: NON-TRANSFERABLE

| PERMIT | INSPECTION FEE | OCCUPATION TAX | LICENSE | TOTAL |
|---|---|---|---|---|
| $ 30.00 | $ | $ | $ | $ 30.00 |
| ACCOUNTING NO. | ACCOUNTING NO. | ACCOUNTING NO. | CODE | |
| 624-1535 | 110.16 | 148.14 | 6-2 | |

| SERIAL NO. | DATE | AMOUNT |
|---|---|---|
| 48799 | [illegible] | 30.00 |

VALID RECEIPT ONLY IF MACHINE RECEIPTED IN THIS SPACE

HEALTH APPLICATION

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☒
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 30.00

FILE NO. 1321

DATE: 5-22-78

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 10 North; Range 8 East; Section 18;
   Block 1 : Lot 3 : Addition Dagley Replat
   Street Address Rt 2, Gary Court

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 3. Describe

3. Type of Individual Sewage Disposal System: Septic Tank ☒ ; Other ☐

4. Distance to public sewer: 2½ miles ~~ft.~~

Steven Dagley
Signature of Applicant (Owner or Lessee)

Rt 2 Gary Court
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 5/22/78. Date Frwd. 5/23/78. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk Date Rec'd. 5-23-78. Date Frwd. ____. ACTION: Approved ☒ Disapproved ☐ Signature: Tom Baasch

3. City ~~or County~~ Engineer : Date Rec'd. 5-23-78. Date Frwd. 5-23-78. ACTION: Approved ☒ Disapproved ☐ Signature: Al Long

REMARKS OR REASONS FOR DISAPPROVAL

Site Visits:
Date: 10-31-78 by: jm
Date: ____ by: ____
Date: ____ by: ____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 11-6-78 By: James Neveka

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

**C**

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 1321

Indicate on sketch if residence and well are exisiting or proposed.




REVIEWING ACTION

Remarks: _____

_____

Date: _____

Minimum Design Requirement
1. Capacity of Septic Tank _____ gals.
2. Total Length of Laterals _____ ft.
3. With a Trench Width of _____ in.
4. Total Area of Lateral needed _____ sq.ft.

_____
Signature of Reviewing Official

FORM 20104-0477
PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☐

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

D

DATE: 11-2-78

FILE NO. _____

Steven Dagley
120 Eastlight Circle Tele 477-3318
Lincoln, Nebr


SPECIFICATIONS AS BUILT

A. BUILDING SEWER:
1. Material Plastic; Diameter 4 in.
2. Distance above basement floor _____ in., or below basement floor 36 in.
3. Distance between dwelling and septic tank 88 ft.
4. Number of clean-outs 2.
5. Distances to:
Well or Suction Line 70 ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

B. SEPTIC TANK:
1. Material Fiberglass No. of compartments one.
2. Capacity 1500 gals.;
3. Factory Built: Yes ☒ No ☐
(Company Carr-A-Glass)
4. Manholes: Over Inlet; diam. 16 in.
Over Outlet; diam. 8 in.
Riser Above ☐ Below ☐ Grade ___ in.
5. Inlet: Baffle ☒ ; or Tee ☐
6. Outlet: Baffle ☐ ; or Tee ☒
7. Depth of top of tank below finished grade 24 in.
8. Distances to:
Well or Suction Line 150 ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.

C. DISTRIBUTION BOX:
1. Material Plastic; Number - available outlets 7.
2. Factory Built: Yes ☒ No ☐
(Company _____)
3. Distance from Septic Tank 5'8" ft.

D. ABSORPTION FIELD: (Provide as built drawings on back of this form)
1. Type: Half Rounds ☒ Perforated Pipe ☐
Diameter of Half Round 12" or Perforated Pipe _____.
Material: fiberglass ☒ ; plastic ☐ ; concrete ☐ ; other _____.
2. Lateral Lines:
Number __ ; Length of each line 100, 102, _____, _____, _____ ft.;
Total length of laterals 202 ft.;
Distance between lateral lines 4 ft.
3. Trench dimensions: Width 4 ft.; Slope 1 in/100 ft.; Average Depth 36" to 24" in.
4. Filter Material: Road Gravel
Depth of Material 16 in.
5. Distances to:
Well or Suction Line 105 ft.; Stream _____ ft.; Pressure Line _____ ft.; Property Line _____ ft.




TYPICAL INDIVIDUAL SEWAGE SYSTEM DESIGN

AS BUILT DRAWING OF SYSTEM

DATE 11-2-78 INSTALLER [signature]

