LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1355-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

January 10, 1979 — THIS PERMIT EXPIRES

Brad Southwick, 701 E. 4th St., Hickman, NE (for Ron Ronhovde) — ISSUED TO / ADDRESS

T10N; R8E; Sect. 22 S½; Lot 10 I.T. — LEGAL DESCRIPTION

REMARKS: NONTRANSFERABLE (EXTEND)

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 15.00	$	$	$ 15.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY | DATE | AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

Health — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 475-6221)

FILE NO. 1355-C

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: _____

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☒, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10N ; Range 8E ; Section ~~21~~ 22 S½ ;
Block _____; Lot LOT 102 Addition _____
Street Address _____

2. Property Use: Residential _____ ☑; Commercial _____ ☐
No. Bedrooms 3 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: EXTEND LATERAL FIELD 200'

5. Work to be done by: Owner ☐ ; or Contractor ☒, BIG CLYDE SANITATION
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	over $200.00

Ron Ronhovde
Eagle, Ne

Brad Southwick
Signature of Applicant (owner or lessee)

701 E 4th Hickman, Ne
Address

(Do not write below this line)

REVIEWING ACTION

1. Date Rec'd: _____
Filing Fee: $ 15.00

2. Site Visits:
Date: 3-25-81 by: rm
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐
by: Gerald C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 3-25-81* by: Ron Morgan

* no visible malfunction at this time.

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. 1355-C

PROPERTY WHERE SOIL TESTED:

Location: Township 10 N ; Range 8E ; Section & ¼ Section 22 . 5½
Property Dimensions: _____ ft. x _____ ft. Area: _____ acres. (Attach Sheet C with sketch of property).

Soil Type: Silty Clay ☐ ; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; ShD Clay Loam ☐ .

Dates of Tests: 6/14/78 to 6/15/78 . Weather: Precip. 0 Temp. 90's.

BILL KIMBALL
REAL ESTATE
800 So. 13 LN, NE

OWNER: Ron Rowlands

Address: _____

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Date (Mo./Day)	Time (Hr./Min.)	Water Level (in.)	Time (Hr./Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	30"	6/14	11:00	[redacted]	1:00	6/15	4:30	20 5/8	5:00	21 1/4	30	5/8	48
2			AM	6/15	PM		PM	23 3/4	PM	25		1 1/4	24
3								24 1/2		24 7/8		3/8	80
4								24 3/4		25 3/4		1"	60
5								27 3/4		29 1/4		1 1/2	20
6								25 1/4		26 1/8		7/8	33

Brad Sonderup
Signature of Person Conducting Test

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Address 701 E 4th, Hickman Phone 792-2462

(Do not write below this line) Need 194' 4' wide

REVIEWING ACTION


Approved Percolation Rate (a)
A. 32 min./inch
B. _____ min./inch
C. _____ min./inch

Remarks: _____

Soil Type (SCS): ShD, possibly some Cp

Date: extends into area "Perk Rate" appears somewhat fast for Sharpsburg soil. Extra lateral could be added.

Ronald Mayer
Signature of Reviewing Official


POND
FENCE
25'
HOUSE
GARAGE
BARN
BARN
FENCE
20'
TANK & RISER
40'
DRAIN
FENCE
PROPERTY LINE
3'
6'
8'
100'
112'
100'
108'
DRIVEWAY
WIND MILL
BARN
PROPERTY LINE
NATURAL GAS LINE
"O" STREET