LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

2200 St. Marys Ave Lincoln, NE 68502-3785 (402) 441-8000

NON TRANSFERABLE

PERMIT

Permit
SEWAGE SYSTEM REPAIR

No. 93390033901

Issued 08/16/93
Expires 02/16/94
Revenue Code 18754

Establishment
BRAD SOUTHWICK
T10N R8E SEC 27

FEES: $50.00

TOTAL $50.00

Permittee
BRAD SOUTHWICK
701 E 4TH ST
HICKMAN NE 68372

Issued By M. Jane Ford
Health Director

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW
"POST IN A PROMINENT PLACE"

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO. _____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 8-3-93

The undersigned hereby applies for a permit to ALTER ☒, EXTEND ☐, or REPAIR ☐ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 10N ; Range 8E ; Section 27 NE¼ ;
Block _____; Lot _____; Addition _____
Street Address _____

2. Property Use: Residential _____ ☒; Commercial _____ ☐
No. Bedrooms 3 Describe _____
Other Use ☐
Describe _____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☒; Other ☐

4. Description of proposed alteration, extension or repair: add Seepage Bed
it Side of existing Lateral

5. Work to be done by: Owner ☐ ; or Contractor ☒, Southwick Sewer & Drain
Contractor's Name

6. Estimated cost of project:

a. Materials	$	
b. Labor	$	
c. Other	$	
TOTAL	$	800 00

Wm Hunt by Brad Southwick
Signature of Applicant (owner or lessee)

701 E 4
Address
Hickman, Ne 68372

(Do not write below this line)

REVIEWING ACTION


1. Date Rec'd: _____
Filing Fee: $ 50.00

2. Site Visits:
Date: 8/3/93 by: J.C.H.
Date: _____ by: _____
Date: _____ by: _____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold C. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL ☒
Date: 8/17/93 by: J.C. Hood

* EXPERIMENTAL ADDITION
HENCE PROVISIONAL APPROVAL


8-93
Leakage area abandoned & covered up
Seepage bed 8-93
Electric Line
16'
15½'
½ round Concrete lateral
1000 gallon Pre Cast Tank
8'
64'
100'
Shell

006

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St. Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

For Refinance of Home Loan

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☐ Evaluation of the Individual Water System Date: 9/11/92

☒ Evaluation of the Sewage Disposal System ☐ Enclosed is $150.00

Legal Description of Property: TWP. ~~27~~ 10N; RANGE ~~10~~ 8E; SECTION ~~8~~ 27; BLOCK ____

LOT 14; ADDITION ____; Street Address 221 So. 162nd

Directions to Property Approx 5mi east of Linc.

Location of Well ____ Tap Location: Inside ☐ Outside ☐

Location of Sewage System ____ Year Installed ____

	NAME	ADDRESS	PHONE
Present Owner:	Bill Hunt	221 So. 162nd	(W) 467-5321
Tenant/Buyer:			(H) 488-7023
Return to:			465-7079

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant For Bill Hunt Jim Lusk Address ____

Lewis and Clark Survey

==========

HEALTH DEPARTMENT USE ONLY

Date Received 09/14/92 Received $150.00 Check ☒ #32853 Cash ☐

PRELIMINARY STATUS--DATE 9-15-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☐	☐	Approved:	☐	Date 9-15-92 by P.D
Bacteria	☐	☐	Provisional:	☐	Date ____ by ____
Nitrate	☐	☐	Disapproved:	☑	Date ____ by ____

Comments: Sewage running out onto ground surface

Repairs to sewage system made (see attached)

See Attached Letter ☐

FINAL STATUS

WATER SYSTEM: Approved: ☒ rural water

SEWAGE DISPOSAL SYSTEM: Approved: ☐ Provisional Approval: ☒

APPROVED BY Paul Dratzmann DATE 9-1-93

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832