LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

FILE NO. 1357-C

INDIVIDUAL SEWAGE SYSTEM CONSTRUCTION — TYPE OF PERMIT

January 10, 1979 — THIS PERMIT EXPIRES

Dale Heidtbrink — ISSUED TO

Malcolm, NE 68402 — ADDRESS

T11N; R5E; Sect. 8 - E 380' of S 647' of S½ of NE¼, except E 40' — LEGAL DESCRIPTION

REMARKS: NONTRANSFERABLE

PERMIT	INSPECTION FEE	OCCUPATION TAX	TOTAL
$ 30.00	$	$	$ 30.00
ACCOUNTING NO.	ACCOUNTING NO.	ACCOUNTING NO.	CODE
	110.16	148.14	6-2

RECEIPTED BY — DATE — AMOUNT

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE

Health — ISSUING OFFICER

THIS PERMIT IS ISSUED AS PROVIDED BY COUNTY RESOLUTION NO. 2832

20109-0977

FORM 20103-0477
REQUEST FOR SITE CLEARANCE AND PERMIT
FOR INDIVIDUAL SEWAGE DISPOSAL SYSTEM
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

A

FILING FEE: $ 30.00

FILE NO. 1357-C

DATE: _____

The undersigned hereby requests SITE CLEARANCE and PERMIT to construct an Individual Sewage Disposal System in conformance with appropriate resolution or ordinance, as described herein:

1. Legal description of property: Twp. 11N ; Range 5E ; Section 8 ;
   Block _____ : Lot _____ : Addition SEE ATTACHED
   Street Address _____

2. Property Use: Residential ☒ ; Commercial ☐ Other Use ☐
   No. of Bedrooms 2 . Describe _____

3. Type of Individual Sewage Disposal System: Septic Tank ☑ ; Other ☐

4. Distance to public sewer: _____ ft.

Dale H. Eidebink
Signature of Applicant (Owner or Lessee)

Malcolm Nebraska 68402
Address

(Do not write below this double line)

1. Health Department: Date Rec'd. 7/10/78. Date Frwd. 7/10/78. ACTION: Approved ☒ Disapproved ☐ Signature: Jerrold C. Hood

2. Supt. Bldg. Insp.: or Village Clerk: Date Rec'd. 7/10/78. Date Frwd. 7/10/78. ACTION: Approved ☑ Disapproved ☐ Signature: Gary N. Shemwell

3. City or County Engineer: Date Rec'd. 7-10-78. Date Frwd. 7-10-78. ACTION: Approved ☑ Disapproved ☐ Signature: Henry Graff

REMARKS OR REASONS FOR DISAPPROVAL _____

Site Visits:
Date: 9-8-78 by: jw
Date: _____ by: _____
Date: _____ by: _____

White: Health Dept. Copy
Yellow: Engineers Copy
Pink: Bldg. Inspector's Copy

INSTALLATION FINAL WRITTEN APPROVAL
Date: 9-18-78 By: James Newcka

FORM 20105-0477
SOIL ABSORPTION TEST DATA REPORT
(Annex to Application)
(Reference: City Ordinance No. 9150 and County Resolution No. 2832)

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

B

FILE NO. 1357-C

PROPERTY WHERE SOIL TESTED:

Location: Township 11N ; Range 5E ; Section & ¼ Section 8.
Property Dimensions: 340' ft. x 647 ft. Area: 5.05 acres. (Attach Sheet C with sketch of property).
Soil Type: Silty Clay ☑; Silty Clay Loam ☐ ; Sandy Loam ☐ ; Silt Loam ☐ ; Clay Loam ☐ .
Dates of Tests: 7-7-78 to 7-8-78. Weather: Precip. 0 Temp. 79.

OWNER: Dale Heidbrink
Address: Malcolm Nebr. 68402

PERCOLATION TEST DATA TABLE

a.	b.	c.	d.	e.	f.	g.	h.	i.	j.	k.	l.	m.	n.
		Pre-Saturation Period				Percolation Readings						Results	
		Start		End		Start			End				
Hold No.	Hole Depth (in.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Date (Mo./ Day)	Time (Hr./ Min.)	Water Level (in.)	Time (Hr./ Day)	Water Level (in.)	Elapsed Time (Min.)	Water Level Drop (in.)	Percolation Rates (Min./in.)
1	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 Noon	3"	240	3	
2	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 "	2½"	240	3½	
3	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 "	empty	240	6	
4	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 "	7/8"	240	5⅛	
5	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 "	empty	240	6	
6	36"	7-7	4PM	7-7	9PM	7-8	8AM	6"	12 "	2⅞"	240	3⅛	

Sum of Percolation Rates: _____
Average of Rates: _____
Mean of Rates: _____

Dale Heidbrink
Signature of Person Conducting Test

Address Malcolm Nebr. Phone 796-2197

(Do not write below this line)

REVIEWING ACTION

Remarks: _____
Soil Type (SCS): Sharpsburg Silty Clay Loam
Date: July 10, 1978

Approved Percolation Rate (a)
A. 5.3 min./inch
B. _____ min./inch
C. _____ min./inch

Gerrold C. Hood
Signature of Reviewing Official

FORM 20102-0477
PRELIMINARY PLANS & SPECIFICATIONS FOR SEWAGE DISPOSAL SYSTEM (Annex to Application)
City Ordinance No. 9150 ☐
County Resolution No. 2832 ☑


LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Avenue
Lincoln, Nebraska 68502
Phone: 474-1541

C

Sketch of property showing Percolation Test hole locations, well, residence, direction and property line.

FILE NO. 1357-C

Indicate on sketch if residence and well are exisiting or proposed.



REVIEWING ACTION

Remarks: _____

Date: July 10, 1978


Minimum Design Requirement
1. Capacity of Septic Tank 1000 gals.
2. Total Length of Laterals 156 ft.
3. With a Trench Width of 48 in.
4. Total Area of Lateral needed 625 sq.ft.

Jerrold C. Hood
Signature of Reviewing Official

South

Dale Heidtbrink
Malcolm Nebraska

T11N R5E Sec 8




north

78-156

Dale A Heidtbrink

File #1357-C



An irregular tract of land situated inthe South half of the northeast quarter of section 8, T11N R5E of the 6th. P.M., Lancaster County, Nebr., more particularly described as follows;

The east 380' of the south 647' of the S½ of the NE¼ of sec. 8, T11N R5E of the 6th. P.M., Lancaster County, Nebr., except the east 40' thereof, the said tract containing 5.05 acres more or less.