LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

Division of Environmental Health
2200 St. Marys Ave Lincoln, NE 68502 (402) 471-8000

NON TRANSFERABLE

PERMIT
SEWAGE SYSTEM REPAIR

No. 92390026901

Issued 02/26/92
Expires 08/28/92

ESTABLISHMENT
PHILLIP EDDY
T11N R5E SEC 7
13601 W/MILL ROAD

FEES: Permit 018754 $50.00

Total $50.00

PERMITTEE
PHILLIP EDDY
13601 W MILL RD
MALCOLM NE 68402

Issued By COUNTY HEALTH

VALID RECEIPT ONLY IF RECEIPTED IN THIS SPACE	
DATE	AMOUNT
2-28-92	pd.

THIS LICENSE OR PERMIT IS ISSUED SUBJECT TO REVOCATION AS PROVIDED BY LAW

FORM HD-41(73) APPLICATION FOR PERMIT TO ALTER, EXTEND OR REPAIR INDIVIDUAL SEWAGE DISPOSAL SYSTEM

City Ordinance No. 9150 ☐
County Resolution No. 2832 ☒

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT
Division of Environmental Health
2200 St. Marys Ave.
Lincoln, Nebraska 68502 (Phone: 471-7800)

FILE NO._____

TO: Division of Environmental Health
Lincoln-Lancaster County Health Dept.

DATE: 2/25/92

The undersigned hereby applies for a permit to ALTER ☐, EXTEND ☐, or REPAIR ☑ an existing Individual Sewage Disposal System, in conformance with appropriate Ordinance or Resolution, as described in this application and drawings attached hereto.

1. Legal description of property: Twp. 11N; Range 5E; Section 7;
Block_____; Lot_____; Addition_____
Street Address 13601 West Mill Rd - Malcolm Ne 68402

2. Property Use: Residential_____ ☑; Commercial_____ ☐
No. Bedrooms 4
Describe_____
Other Use ☐
Describe_____

3. Type of existing Individual Sewage Disposal System: Septic Tank ☑; Other ☐

4. Description of proposed alteration, extension or repair:
Installed two 100 ft subsurface laterals (3ft wide)
20 ft sewer line 18" to 24" deep

5. Work to be done by: Owner ☐; or Contractor ☑, _____
Contractor's Name

6. Estimated cost of project:

a. Materials	$_____
b. Labor	$_____
c. Other	$_____
TOTAL	$_____

Phillip J Eddy phillip Eddy
Signature of Applicant (owner or lessee)

13601 West Mill Rd - Malcolm Ne 68402
Address

(Do not write below this line)


REVIEWING ACTION

1. Date Rec'd: 2-25-92
Filing Fee: $ 40.00

2. Site Visits:
Date: Feb-92 by: mm
Date: 3-26-92 by: mm
Date:_____ by:_____

3. Date: Approved ☒; Disapproved ☐
by: Jerrold E. Hood

4. INSTALLATION FINAL WRITTEN APPROVAL
Date: 3-26-92 by: Ron Yoquem


1000 gal tank
100' Lateral
100' sewer
new Bx 1992
18'
old 100' Lot
20' sewer
New Bx
New 100' Lot
New 100' Lot
3' wide
3' wide

005

LINCOLN-LANCASTER COUNTY HEALTH DEPARTMENT

2200 St Marys Avenue Phone (402) 471-7800 Lincoln, Nebraska 68502

REAL ESTATE TRANSFER / LOAN APPROVAL

This form must be completed and returned to request a real estate transfer inspection.

MAKE CHECKS PAYABLE TO: Lincoln-Lancaster County Health Department.

☑ Evaluation of the Individual Water System Date: 2/15/92

☑ Evaluation of the Sewage Disposal System ☑ Enclosed is $150.00

Legal Description of Property: TWP. 11N; RANGE 5E; SECTION 7; BLOCK ____

LOT ____; ADDITION _____; Street Address 13601 WEST MILL RD. MALCOLM, NE

Directions to Property 3 North of Malcolm on NW 112TH ST & THEN 1 3/4 mile West on Mill Rd - South side of Rd - Brick Home

Location of Well West of house in Pine trees Tap Location: Inside ☐ Outside ☐

Location of Sewage System East of House Year Installed 81

	NAME	ADDRESS	PHONE
Present Owner:	Phillip J. Eddy	13601 WEST MILL RD, MALCOLM, NE	796-2405
Tenant/Buyer:			
Return to:	Phillip J. Eddy	13601 West Mill RD, MALCOLM, NE 68402	796-2405

NOTE: Allow two weeks for processing. Incomplete information will delay processing.

Signature of Applicant Phillip J Eddy Address 13601 West Mill Rd, MALCOLM NE 68402

==========

HEALTH DEPARTMENT USE ONLY

Date Received FEBRUARY 18, 1992 Received $150.00 Check ☒ Cash ☐

PRELIMINARY STATUS--DATE 2-19-92

WATER SYSTEM:	Approved	Disapproved	SEWAGE SYSTEM:		SITE VISIT:
Construction	☒	☐	Approved:	☐	Date 2-19-92 by rm & m
Bacteria	☒	☐	Provisional:	☒ corrected 3-26-92	Date 2-21-92 by rm
Nitrate	☒ 5.2ppm	☐	Disapproved:	☒	Date _____ by ____

Comments: Sewage violation must be corrected. Owner has taken out and paid fee for repair of failing sewage system and assured staff that problem will be corrected very soon. operation completed See Attached Letter ☐

FINAL STATUS * Original sewage system construction was an experimental system.

WATER SYSTEM:	SEWAGE DISPOSAL SYSTEM:*	
Approved: ☒	Approved: ☐	Provisional Approval: ☒*

APPROVED BY Ron Marquardt, R.S. DATE 2-25-92

Approval or disapproval is based on written standards for construction, location and water quality. Inspection is based on visible construction and operation at the time of inspection. Approval or provisional approval does not imply or express a guarantee of system operation. WELLS - Nebraska Safe Drinking Water Act,
- Standards for A Private Well in Nebraska

FG.4120 INDIVIDUAL SEWAGE SYSTEMS - County Resolution #2832